

**ORDINANCE NO. 3-2021**

**AN ORDINANCE AMENDING SECTION 30.05, AUTOMATIC FIRE EXTINGUISHING  
EQUIPMENT REQUIRED FOR FOOD SERVING ESTABLISHMENTS  
NFPA 96, NFPA 1 (50) UL-300, IN THE BEAVER DAM MUNICIPAL CODE**

**THE COMMON COUNCIL OF THE CITY OF BEAVER DAM DO ORDAIN AS FOLLOWS:**

**SECTION I:** Section 30.05, Automatic fire extinguishing equipment required for food service establishments NFPA 96, NFPA 1 (50) UL-300, subparagraph 1 is amended in its entirety as follows:

1. Every kitchen operated and maintained to serve the public, and occupants, including: restaurants, clubs, school, churches, taverns, hospitals, nursing homes, CBRF's and Assisted Living Facilities, need an automatic fire extinguishing system with an exhaust hood. All other places having equipment used for frying, cooking and similar preparation of food, operated and maintained for serving the public shall be subject to this ordinance. Mobile food kitchens, as defined in Wisconsin Food Code 1-201.10(b), that meet SPS 314.50 exceptions would not require a hood system:

- A. The kitchen is less than 365 sq. ft.
- B. The kitchen is used no fewer than 12 days in a calendar year.
- C. A record demonstrating compliance with item 1B above is available upon request.

**SECTION II:** Said ordinance shall be effective upon its passage and publication.

First Reading – March 1, 2021

Adopted: March 15, 2021

Approved: March 15, 2021

---

Zachary Bloom  
Director of Administration/City Clerk

---

Rebecca Glewen  
Mayor

**AFFIDAVIT OF PUBLICATION**

**STATE OF WISCONSIN  
CITY OF BEAVER DAM  
COUNTY OF DODGE)**

ss

Rebecca McBride, being duly sworn, doth depose and say that she is an authorized representative of Capital Newspapers, publishers of the Daily Citizen newspaper, in the City of Beaver Dam, in said County and State, and that an advertisement of which the annexed is a true copy, taken from said paper, was published therein on March 20, 2021.