



**City of Hampton, Virginia**  
**Ordinance - Coded**

22 Lincoln Street  
Hampton, VA 23669  
[www.hampton.gov](http://www.hampton.gov)

File Number: 14-0146

Enactment Number: 14-0003

**Ordinance To Amend And Reenact Chapter 36 Of The Code Of The City Of Hampton, Virginia Entitled "Swimming Pools", By Amending Section 36-51 "Outlet Drain" To Make Consistent With New Stormwater Regulations.**

BE IT ORDAINED by the City Council of Hampton, Virginia, that the Code of the City of Hampton, Virginia, be amended and re-enacted to read as follows:

...

**Sec. 36-51. - Outlet drain.**

Each public swimming pool shall be provided with an outlet drain located at the deepest point in the pool. It shall be capable of emptying the entire contents of the pool. Direct connection to a sanitary sewer or septic tank shall not be permitted. The outlet drain shall be covered with a grate of such design that it cannot be readily removed by, or produce any hazard to, the bathers. Pool water must be de-chlorinated and filtered prior to disposal. Disposal of pool water to a storm sewer or natural watercourse shall be subject to written approval by the director of public health, having regard for the health, safety and public welfare and applicable city and state code provisions.

Adopted at the regular meeting of the City Council of the City of Hampton, Virginia held on April 9, 2014.

**Signed by** \_\_\_\_\_  
George E. Wallace, Mayor

**Date** \_\_\_\_\_

**Attested by** \_\_\_\_\_  
Katherine K. Glass, CMC  
Clerk of the Council

**Date** \_\_\_\_\_