

**ORDINANCE NO. 2019-12**

**AN ORDINANCE OF THE CITY COUNCIL OF THE CITY OF EASTVALE, CALIFORNIA, ADOPTING THE 2019 CALIFORNIA FIRE CODE WITH APPENDICES AND AMENDMENTS THERETO AND AMENDING IN FULL TITLE 110, CHAPTER 110.20 OF THE EASTVALE MUNICIPAL CODE**

**THE CITY COUNCIL OF THE CITY OF EASTVALE DOES ORDAIN AS FOLLOWS:**

**Section 1.** The City Council declares as follows:

**WHEREAS**, at the regular meeting on November 13, 2019, the Eastvale City Council conducted a public hearing and received and considered oral and written testimony concerning the proposed code change; and

**WHEREAS**, the California Health and Safety Code requires cities and counties to adopt building standards that are consistent with those contained in the California Code of Regulations Title 24 ; and

**WHEREAS**, modifications and/or amendments to Chapter 110.20 of the Eastvale Municipal Code requires findings stating that they are found reasonably necessary because of climatic, geological or topographical conditions in the City of Eastvale; and

**WHEREAS**, State law allows local governments to amend California Model Codes, providing the amendments are more restrictive and are necessary in order to provide the highest level of life-safety standards and requires that local governments enforce these code editions.

**Section 2.** The City Council of the City of Eastvale finds as follows:

A. California Health and Safety Code, Section 17958.5 and 18941.5 authorize cities and counties to modify the California Building Standards Code by adopting more restrictive standards and modifications if such standards and modifications are accompanied by express findings that they are reasonably necessary because of local climatic, geological or topographical conditions.

B. The City Council of the City of Eastvale finds that these local climatic. Geological or topographical conditions include, but are not limited to, the following:

I. Climatic Conditions:

A. The City of Eastvale located in Riverside County is located in Southern California and covers a vast and varied geographic area. The base climate in western Riverside County consists of semi- arid Mediterranean weather patterns. Eastern Riverside County is a desert area

with Mohave Desert temperatures and weather patterns. Those two primary areas are divided by the San Bernardino Mountain Range. Both areas outside of the mountain terrain annually experience extended periods of high temperatures with little or no precipitation. Hot, dry winds, which may reach speeds of 70 M.P.H. or greater, are common to the area. Examples are: Santa Ana/ Foehn winds, afternoon surface-heating generated winds, and prevailing desert winds.

These climatic conditions cause extreme drying of vegetation and common building materials. Frequent periods of drought and low humidity add to the fire danger. This predisposes the area to large destructive fires (conflagration) which necessitates rapid identification, locating and extinguishment of all fires in the smallest stage possible. In addition to directly damaging or destroying buildings, these fires are also prone to disrupt utility services throughout the County. Obstacles generated by a strong wind, such as fallen trees, street lights and utility poles, will greatly impact the response time to reach an incident scene. During these winds, the inability to use aerial type firefighting apparatus would further decrease our ability to stop fires in large buildings and place rescue personnel at increased risk of injury.

B. Although Riverside County and the City of Eastvale occasionally experiences periods of significant drought, the County can also experience periods of substantial rainfall. Annual rainfall varying from three (3) inches in Blythe to over thirty three (33) inches in Pine Cove. When Riverside County does experience heavy rain, or rain over a period of days or weeks, many areas of the County are subject to flooding. Runoff from rain drains either naturally into rivers, washes, and creeks or into flood control facilities. Flash flooding is also a common problem, especially in the Coachella Valley and the easterly portions of the county. Flash flooding is typically associated with short duration, high intensity precipitation events often associated with summer thunderstorms. Such events can occur even during a drought.

C. Water demand in densely populated Southern California far exceeds the quantity supplied by natural precipitation; and although the population continues to grow, the already-taxed water supply does not. California is projected to increase in population by nearly 10 million over the next quarter of a century with 50 percent of that growth centered in Southern California. Due to storage capacities and consumption, and a limited amount of rainfall future water allocation is not fully dependable. This necessitates the need for additional and on-site fire protection features. It would also leave tall buildings vulnerable to uncontrolled fires due to a lack of available water and an inability to pump sufficient quantities of available water to floors in a fire.

D. These dry climatic conditions and winds contribute to the rapid spread of even small fires originating in high-density housing or vegetation. These fires spread very quickly and create a need for increased levels of fire protection. The added protection of fire sprinkler systems and other fire protection features such as identification and notification will supplement normal fire department response by providing immediate protection for the building occupants and by containing and controlling the fire spread to the area of origin. Fire sprinkler systems will also reduce the use of water for firefighting by as much as 50 to 75 percent.



## II. Topographical conditions

A. Natural: The topographical conditions of Riverside County varies from three hundred (300) feet below sea-level, flat desert communities, to mountains over ten thousand (10,000) feet in Alpine-like areas of the San Bernardino Mountain Range. In between these areas, developable slopes of 25 percent and greater generally occur throughout the foothills. Riverside County extends from Orange County to the State of Arizona and is mixed with congested urban areas, rural lands and wild lands. A large number of sensitive habitats for various animal species and vegetation consist within large open space areas between major urban centers that impact building and structure location, which impedes emergency access and response. This variety in regions contributes to an increased emergency response time, which necessitates cooperation between local agencies.

B. Traffic and circulation congestion is an artificially created, obstructive topographical condition, which is common throughout Riverside County.

C. These topographical conditions combine to create a situation, which places fire department response time to fire occurrences at risk, and makes it necessary to provide automatic on-site fire-extinguishing systems and other protection measures to protect occupants and property.

## III. Geological Conditions

Located within Riverside County are several known active and potentially active earthquake faults, including the San Andreas, San Jacinto, and Elsinore Fault. In the event of an earthquake, the location of the epicenter as well as the time of day and season of the year would have a profound effect on the number of deaths and casualties, as well as property damage.

The major form of direct damage from most earthquakes is damage to construction. Bridges are particularly vulnerable to collapse, and dam failure may generate major downstream flooding. Buildings vary in susceptibility, dependent upon construction and the types of soils on which they are built. Earthquakes destroy power and telephone lines; gas, sewer, or water mains; which, in turn, may set off fires and/or hinder firefighting or rescue efforts. The hazard of earthquakes varies from place to place, dependent upon the regional and local geology. Ground shaking may occur in areas 65 miles or more from the epicenter (the point on the ground surface above the focus). Ground shaking can change the mechanical properties of some fine grained, saturated soils, where upon they liquefy and act as a fluid (liquefaction).

A. Previous earthquakes in southern California have been accompanied by disruption of traffic flow and fires. A severe seismic event has the potential to negatively impact any rescue or fire suppression activities because it is likely to create obstacles similar to those indicated under the high wind section above. With the probability of strong aftershocks there exists a need to provide increased protection for anyone on upper floors of buildings.

B. Road circulation features located throughout the County also make amendments reasonably necessary. Located through the County are major roadways, highways and flood control channels that create barriers and slow response times. Hills, slopes, street and storm drain design accompanies with occasional heavy rainfall, causes roadway flooding and landslides and at times may make an emergency access route impassable. There are areas in Riverside County that naturally have extended emergency response times that exceed the 5 minute goal.

California Health and Safety Code Sections 17958.7 and 18941.5 require that the modification or change be expressly marked and identified as to which each finding refers. Therefore the City Council finds that the following table sets forth the 2019 California Fire Code sections that have been modified and the associated local climatic, geological and/or topographical conditions described above supporting the modification.

<b>2016 CODE SECTION</b>	<b>TITLE/SUBJECT</b>	<b>FINDINGS I, II, III</b>
101.4	Severability	Administrative
102.5	Application of the residential code	I, II & III
103.4 and 103.4.1	Liability	Administrative
104.1.1	Authority of the Fire Chief and Fire Department	Administrative
104.12	Authority of the Fire Chief to close hazardous fire areas	Administrative
108.1	Board of Appeals established	Administrative
109.4	Violation and Penalties	Administrative
113.2	Fees	Administrative
113.6	Cost Recovery	Administrative
202	Fire Chief	Administrative
308.1.6.3	Sky Lanterns	I, II & III
503.2.1	Dimensions	Administrative
503.2.2	Authority	Administrative
503.6.1	Automatic opener	Administrative
503.7	Loading areas and passenger drop-offs	Administrative
507.5.7	Fire hydrant size and outlets	I & III
507.5.8	Fire hydrant street marker	I, II & III
508.1, 508.1.1, 508.1.3, 508.1.6, 508.1.8	Fire command center	I, II & III
509.2.1	Minimum clearances	I & III
606.10.1.2	Manual operation	II & III
903.2	Where required (automatic sprinkler systems)	I, II & III
903.3.5.3	Hydraulically calculated systems	I & II
3204.2.1	Minimum requirements for client leased or occupant	I, II & III
4904.3	High Fire Hazard Severity Zone Maps	Administrative
5601.2 and 5608.2	Explosives and Fireworks	Administrative



App Ch B, Table B105.2	Buildings other than one- or two-family dwellings	I, II & III
App Ch C, C103.1	Fire hydrant location	I, II & III

**Section 3.** TITLE 110, CHAPTER 110.20 of the Eastvale Municipal Code is amended in full to read as follows:

**Sections:**

110.20.010 - Findings and adoption of the California Fire Code.

110.20.020 - Amendments to the California Fire Code.

110.20.030 - Penalties.

Sec. 110.20.010. Findings and adoption of the California Fire Code.

Except as stated in this Section or as amended below in Section 5 of this ordinance, all of the provisions and appendices of the 2019 California Fire Code, inclusive of all of the inclusions and exclusions set for in each chapter's matrix, are hereby adopted and shall apply to the City of Eastvale. In addition, the following provisions that are excluded in the 2019 California Fire Code are hereby adopted - Chapter 1, Division II of the California Fire Code is hereby adopted, except that Section 103.2 and 109.3 are not adopted, and Chapters 3, 25, and Sections 403.12, 503, 510.2, and 1103.2 are adopted.

One certified copy of each of the 2019 California Fire Code are on file in the office of the City Clerk, and any and all references thereto, are adopted as the Fire Code and each and all of the regulations, provisions, penalties, conditions and terms thereof are referred to, adopted and made a part of this chapter, as though fully set forth at length.

The City Council finds that the requirements set out here are reasonable and necessary modifications because of climatic, geological and topographical conditions within the City of Eastvale. The City of Eastvale in co-operation with the Riverside County Fire Department may establish more restrictive standards reasonably necessary to provide fire protection for life and property due to these conditions.

This chapter shall be cited as the "Fire Code" of the City of Eastvale and any references to the "California Fire Code" or "Fire Code" shall be deemed to refer to and apply to this chapter.

Sec. 110.20.020. - Amendments to the California Fire Code.

The codes, chapters, standards and appendices are amended as specifically set forth in the following chapters:

Chapter 1. Scope and administration

Section 101.4 of the California Fire Code is deleted in its entirety and replaced with the following:

**101.4 Severability.** If any provision, clause, sentence or paragraph of this ordinance or the application thereof to any person or circumstances shall be held invalid, such invalidity shall not affect the other provisions of this ordinance which can be given effect without the invalid provision or application, and to this end, the provisions of this ordinance are hereby declared to be severable.

Section 102.5 of the California Fire Code is amended as follows:

**102.5 Application of residential code.** Where structures are designed and constructed in accordance with the California Residential Code, the provisions of this code shall apply as follows:

1. Construction and design provisions of this code pertaining to the exterior of the structure shall apply including, but not limited to, premises identification, fire apparatus access and water supplies. Where interior or exterior systems or devices are installed, construction permits required by Section 105.7 of this code shall apply.
2. Administrative, operational and maintenance provisions of this code shall apply.
3. Automatic fire sprinkler system requirements of this code shall apply to detached accessory buildings 3,600 square feet or greater in accordance with Section 903.2. The provisions contained in Section 903.2.18 of the California Fire Code or Section R309.6 of the California Residential Code may be used for the design of the automatic fire sprinkler system for detached private garages.

Sections 103.4 and 103.4.1 of the California Fire Code are deleted in their entirety and replaced with the following:

**103.4 Liability.** Any liability against Riverside County or City of Eastvale or any officer or employee for damages resulting from the discharge of their duties shall be as provided by law.

Section 104.1.1 is added to Section 104.1 of the California Fire Code to read as follows:

**104.1.1 Authority of the Fire Chief and Fire Department.**

1. The Fire Chief is authorized and directed to enforce all applicable State fire laws and provisions of this ordinance and to perform such duties as directed by the City Council.
2. The Fire Chief is authorized to administer, interpret and enforce this ordinance. Under the Fire Chief's direction, the Riverside County Fire Department is authorized to enforce ordinances of City of Eastvale pertaining to the following:

- 2.1. The prevention of fires.



- 2.2. The suppression or extinguishment of dangerous or hazardous fires.
- 2.3. The storage, use and handling of hazardous materials.
- 2.4. The installation and maintenance of automatic, manual and other private fire alarm systems and fire extinguishing equipment.
- 2.5. The maintenance and regulation of fire escapes.
- 2.6. The maintenance of fire protection and the elimination of fire hazards on land, in buildings, structures and other property, including those under construction.
- 2.7. The maintenance of means of egress.
- 2.8. The investigation of the cause, origin and circumstances of fire and unauthorized releases of hazardous materials.

3. The following persons are hereby authorized to interpret and enforce the provisions of this ordinance and to make arrests and issue citations as authorized by law:

- 3.1. The Unit Chief, Peace Officers and Public Officers of the California Department of Forestry and Fire Protection.
- 3.2. The Fire Chief, Peace Officers and Public Officers of the Riverside County Fire Department.
- 3.3. The Riverside County Sheriff and any deputy sheriff.
- 3.4. The Police Chief and any police officer of any city served by the Riverside County Fire Department.
- 3.5. Officers of the California Highway Patrol.
- 3.6. Code Officers of the City of Eastvale Code Enforcement Department.
- 3.7. Peace Officers of the California Department of Parks and Recreation.
- 3.8. The law enforcement officer of the Federal Bureau of Land Management.

Section 104.12 is added to Section 104 of the California Fire Code to read as follows:

**104.12 Authority of the Fire Chief to close hazardous fire areas.** Except upon National Forest Land, the Fire Chief is authorized to determine and announce the closure of any hazardous fire area or portion thereof. Any closure by the Fire Chief for a period of more than fifteen (15) calendar days must be approved by the Riverside County Board of Supervisors and/or the City Council within fifteen (15) calendar days of the Fire Chief's original order of closure. Upon such closure, no person shall go in or be upon any hazardous fire area, except upon the public roadways and inhabited areas. During such closure, the Fire Chief shall erect and maintain at all entrances to the closed area sufficient signs giving notice of closure. This section shall not prohibit residents or owners of private property within any closed area, or their invitees, from going in or being upon their lands. This section shall not apply to any entry, in the course of duty, by a peace officer, duly authorized public officer or fire department personnel. For the purpose of this section, "hazardous fire area" shall mean public or private land that is covered with grass, grain, brush or forest and situated in a location that makes suppression difficult resulting in great damage. Such areas are designated on Hazardous Fire Area maps filed with the office of the Fire Chief.

Section 106.2 of the California Fire Code is deleted in its entirety and replaced with the following:

**106.2 Schedule of permit fees.** Fees for services and permits shall be as set forth in the City of Eastvale fee schedule.

Section 106.4 is added to Section 106 of the California Fire Code to read as follows:

**106.4 Cost recovery.** Fire suppression, investigation, rescue or emergency medical costs are recoverable in accordance with Health and Safety Code Sections 13009 and 13009.1, as may be amended from time to time. Additionally, any person who negligently, intentionally or in violation of law causes an emergency response, including, but not limited to, a traffic accident, spill of toxic or flammable fluids or chemicals is liable for the costs of securing such emergency, including those costs pursuant to Government Code Section 53150, et seq, as may be amended from time to time. Any expense incurred by the Riverside County Fire Department for securing such emergency shall constitute a debt of such person and shall be collectable by Riverside County in the same manner as in the case of an obligation under contract, express or implied.

Section 109.1 of the California Fire Code is deleted in its entirety and replaced with the following:

**109.1 Board of appeals established.** The Board of Appeals shall be the City Manager. If he or she determines an outside board is needed, he or she shall designate an outside hearing officer to hear the appeal. The Fire Chief shall be notified of any appeal and the Fire Chief or designee shall be in attendance at the appeal hearing. Depending on the subject of the appeal, specialized expertise may be solicited, at the expense of the applicant, for the purpose of providing input to the Appeals Board.

Section 110.4 of the California Fire Code is deleted in its entirety and replaced with the following:

**110.4 Violation and penalties.** It shall be unlawful for any person, firm, corporation or association of persons to violate any provision of this ordinance, or to violate the provisions of any permit granted pursuant to this code or ordinance. Punishments and penalties for violations shall be in accordance with the City of Eastvale ordinances, fee schedule and Health and Safety Code Sections 17995 through 17995.5.

## Chapter 2. Definitions

Section 202, definition of "Fire Chief" in the California Fire Code is deleted in its entirety and replaced with the following:

Fire Chief. The Fire Chief of Riverside County or the Fire Chief's designee.

## Chapter 3. General requirements.



Section 308.1.6.3 is hereby added to the California Fire Code to read as follows:

308.1.6.3 Sky lanterns or similar devices. A person shall not release or cause to be released a sky lantern or similar device.

## Chapter 5. Fire service features

Section 503.2.1 of the California Fire Code is deleted in its entirety and replaced with the following:

**503.2.1 Dimensions.** Fire apparatus access roads shall have an unobstructed width of not less than 24 feet (7315 mm), exclusive of shoulders, except for approved security gates in accordance with Section 503.6, and an unobstructed vertical clearance of not less than 13 feet 6 inches (4115 mm). For additional requirements or alternatives see Riverside County Fire Department Standards and Policies, as may be amended from time to time.

Section 503.2.2 of the California Fire Code is deleted in its entirety and replaced with the following:

**503.2.2 Authority.** The fire code official shall be the only authority authorized to designate fire apparatus access roads and fire lanes and to modify the minimum fire lane access widths for fire or rescue operations.

Section 503.6.1 is added to Section 503.6 of the California Fire Code to read as follows:

**503.6.1 Automatic opener.** New motorized gates shall be provided with means to be automatically opened remotely by emergency vehicle in accordance with Riverside County Fire Department standards and Policies, as may be amended from time to time.

**Exception:** Gates serving individual one- and two-family dwelling parcels.

Section 503.7 is added to Section 503 of the California Fire Code to read as follows:

**503.7 Loading areas and passenger drop-off areas.** On private properties, where fire apparatus access roads are utilized for loading or unloading or utilized for passenger drop-off or pick-up, an additional eight (8) feet of width shall be added to the minimum required width for the fire apparatus access road.

Section 507.5.7 is added to Section 507 of the California Fire Code to read as follows:

**507.5.7 Fire hydrant size and outlets.** As determined by the fire code official, fire hydrant sizes and outlets shall be based on the following:

1. Residential Standard – one (1) four (4) inch outlet and one (1) two and half (2 ½) inch outlet.
2. Super Hydrant Standard – one (1) four (4) inch outlet and two (2) two and one half (2 ½) inch outlet.
3. Super Hydrant Enhanced – two (2) four (4) inch outlet and one (1) two and one half (2 ½) inch outlet.

Section 507.5.8 is added to Section 507 of the California Fire Code to read as follows:

**507.5.8 Fire hydrant street marker.** Fire hydrant locations shall be visually indicated in accordance with Riverside County Fire Department Technical Policy 06-11, as may be amended from time to time. Any hydrant marker damaged or removed during the course of street construction or repair shall be immediately replaced by the contractor, developer or person responsible for removal or damage.

Section 508.1 of the California Fire Code is deleted in its entirety and replaced with the following:

**508.1 General.** Where required by other sections of this code and in all buildings classified as high-rise buildings by the California Building Code, in buildings greater than 300,000 square feet in area and in Group I-2 occupancies having occupied floors located more than 75 feet above the lowest level of fire department vehicle access, a fire command center for fire department operations shall be provided and comply with Sections 508.1.1 through 508.1.8.

Section 508.1.1 of the California Fire Code is deleted in its entirety and replaced with the following:

**508.1.1 Location and access.** The fire command center shall be located adjacent to the main lobby and shall be accessible from fire department vehicular access or as approved by the fire code official. The room shall have direct access from the building exterior at the lowest level of fire department access.

Section 508.1.3 of the California Fire Code is amended to add the following:

**Exception:** A fire command center solely required because a building is greater than 300,000 square feet in area shall be a minimum of 96 square feet (9 m<sup>2</sup>) with a minimum dimension of 8 feet (2438mm).

Section 508.1.6 of the California Fire Code is amended to add the following:

**Exception:** A fire command center solely required because a building is greater than 300,000 square feet in area shall comply with NFPA 72 and contain the features set forth in Section 508.1.6 subsections 5, 8, 10, 12, 13 and 14. The features set forth in Section 508.1.6 subsections 1, 2, 3, 4, 6, 7, 9, 11, 15, 16, 17, 18 and 19 shall be required when such building contains systems or functions related to these features.



Section 508.1.8 is added to Section 508 of the California Fire Code to read as follows:

**508.1.8 Fire command center identification.** The fire command center shall be identified by a permanent easily visible sign stating, "Fire Dept. Command Center," located on the door to the fire command center.

Section 509.2.1 of the California Fire Code is amended to add the following:

**509.2.1 Minimum clearances.** A 3-foot (914 mm) clear space shall be maintained around the circumference of exterior fire protection system control valves, or any other exterior fire protection system component that may require immediate access, except as otherwise required or approved.

## Chapter 6. Building services and systems

Section 606.10.1.2 of the California Fire Code is deleted in its entirety and replaced with the following:

**606.10.1.2 Manual operation.** When required by the fire code official, automatic crossover valves shall be capable of manual operation. The manual valves shall be located in an approved location immediately outside of the machinery room in a secure metal box or equivalent and marked as Emergency Controls.

## Chapter 9. Fire protection systems

Section 903.2 of the California Fire Code is deleted in its entirety and replaced with the following:

**903.2 Where required.** In all new buildings and structures which are 3,600 square feet or greater, an approved automatic sprinkler system shall be provided regardless of occupancy classification. Where the Sections 903.2.1 – 903.2.20 of the California Fire Code require more restrictive requirements than those listed below, the more restrictive requirement shall take precedence.

**Exception:** Unless required elsewhere in this code or the California Building Code, automatic fire sprinkler systems shall not be required for the following:

1. Detached Group U occupancies used for agricultural purposes constructed in accordance with the California Building Code.
2. Detached non-combustible equestrian arena shade canopies that are open on all sides and used for riding only - no commercial, assembly or storage uses.
3. Detached fabric or non-combustible shade structures that are open on all sides and used to shade playground equipment, temporary storage of vehicles and dining areas with no cooking.

4. Where determined by the Fire Chief that no major life safety hazard exists, and the fuel load does not pose a significant threat to firefighter safety or to other structures or property, automatic fire sprinklers may be exempted.

One- and two-family dwellings shall have an automatic fire sprinkler system regardless of square footage in accordance with the California Residential Code. Fire sprinkler systems shall be installed in mobilehomes, manufactured homes and multifamily manufactured homes with two dwelling units in accordance with Title 25 of the California Code of Regulations.

The following exceptions in the California Fire Code shall not be allowed:

- a. Exception in Section 903.2.3
- b. Exception 2 in Section 903.2.11.3

Section 903.3.5.3 is added to Section 903 of the California Fire Code to read as follows:

**903.3.5.3 Hydraulically calculated systems.** The design of hydraulically calculated fire sprinkler systems shall not exceed 90% of the water supply capacity.

Chapter 32. High-piled combustible storage

Section is added to Section 3204.2 of the California Fire Code to read as follows:

**3204.2.1 Minimum requirements for client leased or occupant owned warehouses.** Designs of an automatic sprinkler system for client leased or occupant owned buildings containing high pile storage shall be based on the requirements of NFPA 13. The responsible fire protection engineer shall perform a survey of the building to determine commodity classification, storage configuration, building height and other information related to the development of an appropriate sprinkler system design. The fire protection engineer shall also make reasonable efforts to meet with the building owner or operator to understand seasonal or customer related fluctuations to the stored commodities, storage height, and configuration. The sprinkler design shall be based on the most demanding requirements determined through the onsite survey and discussions with the building owner or operator. The technical report shall describe the basis for determining the commodity and sprinkler design selection, how the commodities will be isolated or separated, and include references to the design document(s). If a specific fire test is used as the basis of design, a copy of the fire test report shall be provided at the time of plan review.

Chapter 49. Requirements for wildland-urban interface fire areas

Section 4904.3 is added to Section 4904 of the California Fire Code to read as follows:

**4904.3 High Fire Hazard Severity Zone Maps.** In accordance with Government Code Sections 51175 through 51189, Very High Fire Hazard Severity Zones are designated as shown on a map titled Very High Fire Hazard Severity Zones, dated December 24, 2009 and retained on



file at the office of the Fire Chief, which supersedes other maps previously adopted designating high fire hazard areas.

## Chapter 56. Explosives and Fireworks

Section 5601.2 and Section 5608.2 of the California Fire Code are hereby added to read as follows:

Section 5601.2 Retail Fireworks. The storage, use, sale, possession, and handling of fireworks including those classified as Safe & Sane fireworks are prohibited.

Exception: Fireworks may be part of an electrically fired public display when permitted and conducted by a licensed pyrotechnic operator.

## Appendix B.

Table B105.2 of the California Fire Code is amended as follows:

**TABLE B105.2**  
**REQUIRED FIRE-FLOW FOR BUILDINGS OTHER THAN ONE- AND**  
**TWO-FAMILY DWELLINGS, GROUP R-3 AND R-4 BUILDINGS AND TOWNHOUSES**

<b>AUTOMATIC SPRINKLER SYSTEM (Design Standard)</b>	<b>MINIMUM FIRE-FLOW (gallons per minute)</b>	<b>FLOW DURATION (hours)</b>
No automatic sprinkler system	Value in Table B105.1(2)	Duration in Table B105.1(2)
Section 903.3.1.1 of the <i>California Fire Code</i>	50% of the value in Table B105.1(2) <sup>a</sup>	Duration in Table B105.1(2) at the reduced flow rate
Section 903.3.1.2 of the <i>California Fire Code</i>	50% of the value in Table B105.1(2) <sup>b</sup>	Duration in Table B105.1(2) at the reduced flow rate

For SI: 1 gallon per minute = 3.785 L/m.

a. The reduced fire-flow shall be not less than 1,000 gallons per minute.

b. The reduced fire-flow shall be not less than 1,500 gallons per minute.

## Appendix C.

Section C103.1 of the California Fire Code is deleted in its entirety and replaced with the following:

**C103.1 Hydrant spacing.** Fire apparatus access roads and public streets providing required access to buildings in accordance with Section 503 of the International Fire Code shall be provided with one or more fire hydrants, as determined by Section C102.1. Where more than

one fire hydrant is required, the distance between required fire hydrants shall be in accordance with Sections C103.2 and C103.3. Fire hydrants shall be provided at street intersections.

Sec. 110.20.030. - Penalties.

(a) It is unlawful for any person, firm, corporation or association of persons to violate any provision of this chapter, or to violate the provisions of any permit granted pursuant to this chapter. Any person, firm, corporation or association of persons violating any provision of this chapter or the provisions of any permit granted pursuant to this chapter shall be deemed guilty of an infraction or misdemeanor as hereinafter specified. Such person or entity shall be deemed guilty of a separate offense for each and every day or portion thereof during which any violation of any of the provisions of this chapter or the provisions of any permit granted pursuant to this Chapter, is committed, continued or permitted.

(b) Any person, firm, corporation or association of persons so convicted shall be:

(1) Guilty of an infraction offense and punished by a fine not exceeding \$200.00 for a first violation;


(2) Guilty of an infraction offense and punishable by a fine not exceeding \$300.00 for a second violation on the same site.

The third and any additional violations on the same site shall constitute a misdemeanor offense and shall be punishable by a fine not exceeding \$1,000.00 or six months in jail, or both. Notwithstanding the above, a first offense may be charged and prosecuted as a misdemeanor.


(c) Payment of any penalty herein shall not relieve a person or entity from the responsibility for correcting the violation.

Section 4. Effective Date: This Ordinance shall become effective 30 days from the date of its adoption but no sooner than January 1, 2020.

**PASSED, APPROVED AND ORDAINED** this 11<sup>th</sup> day of December 2019.

  
\_\_\_\_\_  
Mayor

APPROVED AS TO FORM:

  
\_\_\_\_\_  
Erica Vega  
City Attorney

ATTEST:

  
\_\_\_\_\_  
Marc A. Denohue, MMC  
City Clerk



STATE OF CALIFORNIA )  
COUNTY OF RIVERSIDE ) §  
CITY OF EASTVALE )

I, Marc A. Donohue, City Clerk of the City of Eastvale, do hereby certify that the foregoing Ordinance Number 19-12 was introduced at a regular meeting of the City Council of the City of Eastvale held on the 13<sup>th</sup> day of November, 2019 and was finally passed by the City Council of the City of Eastvale at a regular meeting held the 11<sup>th</sup> day of December, 2019, by the following vote:

AYES: Councilmembers Lorimore, Rigby, Tessari, Mayor Pro Tem Yow, and Mayor Plott

NOES:

ABSENT:

ABSTAIN:



---

Marc A. Donohue, MMC  
City Clerk