

ORDINANCE NO. 2022-487

**AN ORDINANCE OF THE CITY COUNCIL OF THE CITY OF LOS ALTOS
AMENDING TITLE 12 OF THE MUNICIPAL CODE BY REPLACING CHAPTERS
12.04, 12.08, 12.10, 12.12, 12.16, 12.20, 12.22, 12.24, 12.26, 12.30, 12.32,
12.42 AND 12.68 TO ADOPT BY REFERENCE WITH LOCAL AMENDMENTS
THE FOLLOWING:**

2022 CALIFORNIA ADMINISTRATIVE CODE, PUBLISHED BY THE
INTERNATIONAL CODE COUNCIL;

2022 CALIFORNIA BUILDING CODE, PUBLISHED BY
THE INTERNATIONAL CODE COUNCIL;

2022 CALIFORNIA RESIDENTIAL CODE, PUBLISHED BY
THE INTERNATIONAL CODE COUNCIL;

2022 CALIFORNIA PLUMBING CODE, PUBLISHED BY THE INTERNATIONAL
ASSOCIATION OF PLUMBING AND MECHANICAL OFFICIALS;

2022 CALIFORNIA MECHANICAL CODE, PUBLISHED BY THE INTERNATIONAL
ASSOCIATION OF PLUMBING AND MECHANICAL OFFICIALS;

2022 CALIFORNIA ELECTRICAL CODE, PUBLISHED BY
THE NATIONAL FIRE PROTECTION AGENCY;

2022 CALIFORNIA ENERGY CODE, PUBLISHED BY
THE INTERNATIONAL CODE COUNCIL;

2022 CALIFORNIA FIRE CODE, PUBLISHED BY
THE INTERNATIONAL CODE COUNCIL;

2022 CALIFORNIA GREEN BUILDING STANDARDS CODE PUBLISHED BY
THE INTERNATIONAL CODE COUNCIL;

2022 CALIFORNIA EXISTING BUILDING CODE, PUBLISHED BY
THE INTERNATIONAL CODE COUNCIL;

2022 CALIFORNIA HISTORICAL BUILDING CODE, PUBLISHED BY
THE INTERNATIONAL CODE COUNCIL;

AND 2022 CALIFORNIA REFERENCED STANDARDS CODE, PUBLISHED BY
THE INTERNATIONAL CODE COUNCIL;

**TOGETHER WITH CERTAIN ADMENDMENTS, ADDITIONS, INSERTIONS,
DELETIONS AND CHANGES THERETO.**

WHEREAS, The California Building Standards Commission has published the California Building Standards Code, 2022 edition, as provided in the California Code of Regulations, Title 24, and these State mandated regulations go into effect January 1, 2023; and

WHEREAS, California Health and Safety Code Sections 17958.7 and 18941.5 authorize cities to adopt the California Building Standards Code with modifications determined to be reasonably necessary because of local climatic, geological or topographical conditions; and;

WHEREAS, adoption of these updated versions of the California Code of Regulations, with local amendments as set forth in this ordinance, are necessary to enhance and safeguard public health, safety, general welfare and to provide safety to firefighters and emergency responders during emergency operations as required by the City's unique climatic, geological and topographical conditions; and

WHEREAS, the City held a public hearing on November 15, 2022 at which time all interested persons had the opportunity to appear and be heard on the matter of adopting the Codes as amended herein; and

WHEREAS, the City published notice of the aforementioned public hearing pursuant to California Government Code Section 6066 on October 26, 2022 and November 2, 2022; and

WHEREAS, the Ordinance amendments set forth below have been reviewed and considered by the City Council in accordance with the provisions of the California Environmental Quality Act of 1970, as amended ("CEQA"), and the guidelines promulgated thereunder and, further, said Council finds that it can be seen with certainty that there is no possibility that said amendments may have a significant effect on the environment and said amendments are therefore exempt from the requirements of the CEQA pursuant to the provisions of Section 15061(b)(3) of Division 6 of Title 14 of the California Code of Regulations.

NOW THEREFORE, the City Council of the City of Los Altos does hereby ordain as follows:

SECTION 1. AMENDMENT OF CODE:

TITLE 12. BUILDINGS AND CONSTRUCTION

SECTION 2. AMENDMENT OF CODE: Title 12, Chapter 12.04 of the Municipal Code is hereby repealed.

SECTION 3. AMENDMENT OF CODE: Title 12, Chapter 12.04 of the Municipal Code is hereby added to read as follows:

Chapter 12.04 ADMINISTRATIVE CODE

Section 12.04.010 Adoption of the California Administrative Code.

There is hereby adopted by reference as if fully set forth herein, the 2022 California Administrative Code, contained in the California Code of Regulations, Title 24, Part 1, published by the International Code Council, and each and all of its regulations and provisions. One copy is on file for use and examination by the public in the office of the Building Official.

SECTION 4. AMENDMENT OF CODE: Title 12, Chapter 12.08, of the Municipal Code is hereby repealed.

SECTION 5. AMENDMENT OF CODE: Title 12, Chapter 12.08, of the Municipal Code is hereby added to read as follows:

Chapter 12.08 BUILDING CODE

Section 12.08.010 Adoption of the California Building Code.

Section 12.08.020 Amendments.

Section 12.08.030 Correction of Violations.

Section 12.08.040 Fee Refunds.

Section 12.08.010 Adoption of the California Building Code.

The 2022 California Building Code (2 volumes), contained in the California Code of Regulations, Title 24, Part 2, which incorporates and amends the International Building Code 2021 Edition, published by the California Building Standards Commission and the International Code Council, with the amendments and certain appendices as set forth in Section 12.08.020, is hereby adopted by reference as if fully set forth here. One copy of said code is on file in the office of the Building Official for use and examination by the public.

Section 12.08.020 Amendments.

The 2022 California Building Code referred to in Section 12.08.010 is adopted, together with Chapter 1 of the 2022 California Building Code, with the following amendments and certain Appendix Chapters as follows:

Chapter 1, Division II, Section 105.2 Building: #1, is deleted and replaced to read as follows, based upon the express finding of necessity set forth in Section 6.B.1 of this Ordinance.

A. Work exempt from building permits.

Building permits shall not be required for freestanding unenclosed play structures. Enclosed accessory structures used as playhouses, tool and storage sheds and similar uses that are less than 120 square feet constructed without electrical, plumbing, or mechanical features do not require building permits, but do require zoning approval to comply with local zoning regulations.

Chapter 1, Division II, Section 110.3.4 is deleted and replaced to read as follows, based upon the express findings of necessity set forth in Section 6.B.2 of this Ordinance.

B. Frame Inspection.

Framing inspection shall be made after the following components are completed: Roof deck and/or sheathing has been inspected and approved; complete finish roofing materials are installed; the building exterior envelope has all windows and doors installed; all framing, fire-blocking, bracing, pipes, chimneys and vents to be concealed are complete; and all sub-trades including, but not limited to, building, electrical, plumbing and mechanical are roughed in and under required tests.

C. Only the following Appendix Chapters from the Building Code are adopted:

1. Appendix I, Patio Covers.
2. Appendix J, Grading.

Section 903.2 is amended to read as follows:

903.2 Where required. Approved automatic sprinkler systems in new and existing buildings and structures shall be provided in the locations described in this Section or in Sections 903.2.1 through 903.2.12 whichever is the more restrictive and Sections 903.2.14 through 903.2.21.

For the purposes of this section, firewalls and fire barriers used to separate building areas shall be constructed in accordance with the California Building Code and shall be without openings or penetrations.

1. An automatic sprinkler system shall be provided throughout all new buildings and structures, other than Group R occupancies, except as follows:
 - a. Buildings and structures not located in any Wildland-Urban Interface and not exceeding 1,200 square feet of fire area.
 - b. Buildings and structures located in any Wildland-Urban Interface Fire Area and not exceeding 500 square feet of fire area.
 - c. Group S-2 or U occupancies, including photovoltaic support structures, used exclusively for vehicle parking which meet all of the following:
 - i. Noncombustible construction.
 - ii. Maximum 5,000 square feet in building area.
 - iii. Structure is open on not less than three (3) sides nor 75% of structure perimeter.
 - iv. Minimum of 10 feet separation from existing buildings, or similar structures, unless area is separated by fire walls complying with California Building Code 706.
 - d. Canopies, constructed in accordance with CBC 406.7.2, used exclusively for weather protection of vehicle fueling pads per CBC 406.7.1 and not exceeding 5,000 square feet of fire area.

2. An automatic sprinkler system shall be installed throughout all new buildings with a Group R fire area.

Exception: Detached Accessory Dwelling Unit, provided that all of the following are met:

- a. The unit meets the definition of an Accessory Dwelling Unit as defined in the Government Code Section 65852.2.
 - b. The existing primary residence does not have automatic fire sprinklers.
 - c. The accessory detached dwelling unit does not exceed 1,200 square feet in size.
 - d. The unit is on the same lot as the primary residence.
 - e. The unit meets all apparatus access and water supply requirements of Chapter 5 and Appendix B of the 2022 California Fire Code.
-
3. An approved automatic fire sprinkler system shall be installed in new manufactured homes (as defined in California Health and Safety Code Sections 18007 and 18009) and multifamily manufactured homes with two dwelling units (as defined in California Health and Safety Code Section 18008.7) in accordance with Title 25 of the California Code of Regulations.

4. An approved automatic sprinkler system shall be provided throughout all existing buildings, when additions are made that exceed fifty (50) percent and/or seven hundred and fifty (750) square feet of existing floor areas (area calculations shall not include existing basement floor areas and any non-habitable floor areas i.e., garages).
5. An approved automatic sprinkler system shall be provided throughout all new and existing basements.
6. An approved automatic sprinkler system shall be provided throughout existing buildings and structures when alterations or additions are made that create conditions described in Sections 903.2.1 through 903.2.18
7. Any change in the character of occupancy or in use of any building with a fire area equal to or greater than 3,600 square feet which, in the opinion of the fire code official or building official, would place the building into a more hazardous division of the same occupancy group or into a different group of occupancies and constitutes a greater degree of life safety¹ or increased fire risk², shall require the installation of an approved fire automatic fire sprinkler system.
 - ¹ Life Safety – Shall include, but not limited to: Increased occupant load, public assembly areas, public meeting areas, churches, indoor amusement attractions, buildings with complex exiting systems due to increased occupant loads, large schools/day-care facilities, large residential care facilities housing non-ambulatory clients.
 - ² Fire Risks – Shall include, but not limited to: High-piled combustible storage, woodworking operations, hazardous operations using hazardous materials, increased fuel loads (storage of moderate to highly combustible materials), increased sources of ignition (welding, automotive repair with the use of flammable liquids and open flames).
8. The obligation to provide compliance with these fire sprinkler regulations may not be evaded by performing a series of small additions and/or alterations undertaken over a three-year period and/or two code cycles. The permit issuance dates of past additions and/or alterations where these regulations were in effect shall be used for determining compliance.
 - a. Any submittal for building permits which exceed fifty (50) percent and/or seven hundred and fifty (750) square feet of existing floor areas (area calculations shall not include existing basement floor areas and any non-habitable floor areas i.e., garages) during the three-year period shall comply with fire sprinkler regulations.
 - b. No waiver shall be granted from compliance with fire sprinklers.

Section 903.2.11.7 is amended to read as follows:

903.2.11.7 Chemical Fume Hood Fire Protection. Approved automatic fire extinguishing systems shall be provided in chemical fume hoods in the following cases:

1. Existing hoods having interiors with a flame spread index greater than 25 in which flammable liquids are handled
2. If a hazard assessment determines that an automatic extinguishing system is required for the chemical fume hood, then the applicable automatic fire protection system standard shall be followed.

Section 907.8 is amended to read as follows:

907.8 Inspection, testing and maintenance. The maintenance and testing schedules and procedures for fire alarm and fire detection systems shall be in accordance with Sections 907.8.1 through 907.8.4 and NFPA 72. Records of inspection, testing and maintenance shall be documented using NFPA 72 record of inspection and testing forms.

Section 12.08.030 Correction of Violations.

The issuance or granting of a permit or approval of plans under this Title shall not prevent the administrative authority from thereafter requiring the correction of errors in such plans and specifications, or from preventing construction operations being carried on thereunder when in violation of this Code or of any other law, or from revoking any certificate of approval when issued in error.

- A. The 2022 California Building Code referred to in Section 12.08.010 is adopted, together with Chapter 1 of the 2022 California Building Code, with the following amendments and certain Appendix Chapters as follows:

Chapter 1, Division II, Section 105.5 is deleted and replaced to read as follows, as an administrative clarification, and does not modify a building standard pursuant to California Health & Safety Code Sections 17958, 17958.7 and/or 18941.5 This amendment establishes administrative standards for the effective enforcement of the building standards in the City of Los Altos.

Expiration. Every permit issued shall become invalid unless the work on the site authorized by such permit is commenced within 12 months after its issuance, or if the work authorized on the site by such permit is suspended or abandoned for a period of 12 Months after the time the work is commenced. The building official is authorized to grant, in writing, one or more extensions of time for periods not more than 180 days each. The extension shall be requested in writing and justifiable cause demonstrated.

Before such work can be recommenced, a new permit shall be first obtained, and the fee therefore shall be one-half (1/2) the amount required for a new permit for such work provided no changes have been made, or will be made, in the original plans and specifications for such work; and provided, further, that such a suspension or abandonment has not exceeded one year. In order to renew action on a permit after one year expiration, the permittee shall be required to pay original full building permit fees.

For the purpose of this section, failure to progress a project to the next level of required inspection shall be deemed abandonment of the project.

For those projects that are residential only, the Building Official may modify expired permit fees when the owner can demonstrate that the project has received all required inspections, except for the Building Division final. The fee amount of one hundred dollars (\$100) shall be required within 10 working days of notice and the project shall achieve a final inspection within 30 days of payment received, otherwise expired permit fees as noted above shall be required.

- B. Work commencing before permit issuance. Whenever any work for which a permit is required by the California Code of Regulations as adopted in this chapter has been commenced without first obtaining said permit, the building official shall charge a minimum of two times and/or up to four times, for repeat offenders, on all applicable plan review and permit (inspection) fees related to the required permit(s), including, but not limited to, building permits (including, but not limited to electrical, fire, mechanical and plumbing), sign permits and demolition permits. The legal registered owner of said property shall obtain a building permit within 30 days of any violation letter or stop-work notice issued by the City of Los Altos. The payment of the increased fee(s) shall not relieve any person from fully complying with the requirements of this code, other codes adopted by the City, or the requirements of the zoning ordinance. Failure to comply with the provisions of this chapter may also subject the violator to any other penalties, sanctions or remedies provided elsewhere in this code. This provision shall not apply to emergency work when the administration authority determines that such work was urgently necessary and that it was not practical to obtain a permit therefore prior to the commencement of such work. In such cases, a permit shall be obtained as soon as it is practical to do so; and if there is an unreasonable delay (exceeding two working days) in obtaining such permit, a fee as provided in this section shall be charged.

Once building permits are issued pursuant to work commenced without required permits, it is the responsibility of the permit holder to obtain their first

required building inspection within 30 days from permit issuance date and shall receive a project final inspection within a one-year period. Any further delays will require additional building permit fees charged again in the original amount with an additional 30-day extension. If the project continues without meeting these deadlines, Administration Citation Fees and/or other legal remedies allowed by local, or state law shall be imposed.

Failure to contact the Building Division within five business days of receiving the violation notice may result in Administration Citation Fees, Chapter 1.30 of the Los Altos Municipal Code.

Section 12.08.040 Fee Refunds.

The Building Official may authorize refunding of any fee paid hereunder which was erroneously paid or collected.

The Building Official may authorize refunding of not more than 80 percent of the permit fee paid when no work has been done under a permit issued in accordance with this code.

The Building Official may authorize refunding of not more than 80 percent of the plan review fee paid when an application for a permit for which a plan review fee has been paid is withdrawn or canceled before any plan reviewing is done.

The Building Official shall not authorize refunding of any fee paid except on written application filed by the original permittee not later than 180 days after the date of fee payment.

SECTION 6. AUTHORITY AND FINDINGS.

- A. This Ordinance is enacted pursuant to and in compliance with Health and Safety Code Section 18941.5 and as expressly permitted in Government Code Section 50022.2.
- B. Express Findings as required by Health and Safety Code 18941.5(c.). The City Council of the City of Los Altos hereby expressly finds that amendments to the Building Code adopted by this Ordinance and as described in section 12.08.020 are necessary for the protection of the public health, safety, and welfare, due to the local climatic, geologic, or topographical conditions.
 - 1. Section 105.2 Building: (1) exempts one story detached accessory structures used as tool and storage sheds, playhouses, and similar uses, from obtaining building permits provided the floor area does not exceed 120 square feet.

The Los Altos Municipal Code zoning regulations apply to all accessory structures, regardless of size. All accessory structures are subject to obtaining a zoning approval.

2. The City of Los Altos is a combination inspection jurisdiction; once the framing inspection is approved the building may be insulated. The City of Los Altos is located in climate zone four, due to the local climatic conditions; rain is often forecasted creating ideal conditions for corrosion, moisture to conductors and mold related issues due to wet materials and insulation. Providing a finished roof in addition to installing exterior doors and windows will reduce these negative impacts.

SECTION 7. AMENDMENT OF CODE: Title 12, Chapter 12.10, of the Municipal Code is hereby repealed.

SECTION 8. AMENDMENT OF CODE: Title 12, Chapter 12.10 of the Municipal Code is hereby added to read as follows:

Chapter 12.10 RESIDENTIAL CODE

Section 12.10.010 Residential Code – Adoption of the California Residential Code.

Section 12.10.020. Amendments.

Section 12.10.030 Correction of Violations.

Section 12.10.040 Fee Refunds.

Section 12.10.010 Adoption of the California Residential Code.

The 2022 California Residential Code, contained in the California Code of Regulations, Title 24, Part 2.5, published by the California Building Standards Commission and the International Code Council, which incorporates and amends the 2021 International Residential Code 2021 Edition, is hereby adopted. There is one copy of said code on file in the office of the Building Official for use and examination by the public.

Section 12.10.020 Amendments.

The 2022 California Residential Code referred to in Section 12.10.10 is adopted, together with Chapter 1 of the 2022 California Residential Code, with the following amendments to read as follows:

Chapter 3 Section R301.1.3.2 is deleted and replaced to read as follows, based upon the express finding of necessity set forth in section 9.B.1. of this Ordinance.

R301.1.3.2 Wood frame structures. The building official shall require construction documents to be approved and stamped for structural compliance by a California licensed architect or engineer for all dwellings of wood frame construction more than one story in height located in Seismic Design Category D0, D1, D2, or E.

Chapter 3 Section R313.1 and Section R313.2 are deleted and replaced to read as follows, based upon the express finding of necessity set forth in section 9.B.2. of this Ordinance.

Section R313.1 is amended to read as follows:

R313.1 Townhouse automatic fire sprinkler systems. An automatic residential fire sprinkler system shall be installed in accordance with National Fire Protection Association's (NFPA) Standard 13D in all new townhouses and in existing townhouses, when additions are made that increase the building area to more than the allowable Fire-Flow Appendix B, Tables B105.1(1) and B105.1(2) of the 2022 California Fire Code, and/or additions exceeding fifty (50) percent of the existing living area (existing square foot calculations shall not include existing basement) and/or additions exceeding seven hundred and fifty (750) square feet. When automatic fire sprinkler systems are required by this section, all associated attached garages shall be included. Additions over fifty (50) percent and/or seven hundred and fifty (750) square feet as referenced above, shall be treated as a new structure regarding installation of fire sprinkler systems. For the purpose of this section, removal of roof framing with associated exterior walls down to, or below the subfloor/slab shall be included in the above calculations. Therefore, the following shall apply:

The obligation to provide compliance with these fire sprinkler regulations may not be evaded by performing a series of small additions undertaken over a three-year period. The permit issuance dates of past additions where these regulations were in effect shall be used for determining compliance.

- a. Any submittal for building permits which exceed fifty (50) percent and/or seven hundred and fifty (750) square feet of existing floor areas (area calculations shall not include existing basement floor areas and any non-habitable floor areas i.e., garages) during the three-year period shall comply with fire sprinkler regulations.
- b. No waiver shall be granted from compliance with fire sprinklers.

Section R313.2 is amended to read as follows:

R313.2 One and two-family dwellings automatic fire sprinklers systems. An automatic residential fire sprinkler system shall be installed in accordance with National Fire Protection Association's (NFPA) Standard 13D in all new one and two-family dwellings and in existing dwellings, when additions are made that increase the building area to more than the allowable Fire-Flow Appendix Tables B105.1(1) and B105.1(2) of the 2022 California Fire Code, and/or additions exceeding fifty (50) percent of the existing living area (existing square foot calculations shall not include existing basement) and/or additions exceeding seven hundred and fifty (750) square feet. When automatic fire sprinkler systems are required by this section, all associated garages shall be included. Additions over fifty (50) percent and/or seven hundred and (750) square feet as referenced above, shall be treated as a new structure regarding installation of fire sprinkler systems. For the purpose of this section, removal of roof framing with associated exterior walls down to, or below the subfloor/slab shall be included in the above calculations. Therefore, the following shall apply:

The obligation to provide compliance with these fire sprinkler regulations may not be evaded by performing a series of small additions undertaken over a three-year period and/or two California Building Standards Code Cycles. The permit issuance date of past additions where these regulations were in effect shall be used for determining compliance.

- a. Any submittal for building permits which exceed fifty (50) percent and/or seven hundred and fifty (750) square feet of existing floor areas (area calculations shall not include existing basement floor areas and any non-habitable floor areas i.e., garages) during the three-year period shall comply with fire sprinkler regulations.
- b. No waiver shall be granted from compliance with fire sprinklers.

Exceptions:

1. Detached Accessory Dwelling Unit, provided that all of the following are met:
 - 1.1. The unit meets the definition of an Accessory Dwelling Unit as defined in the Government Code Section 65852.2.
 - 1.2. The existing primary residence does not have automatic fire sprinklers.
 - 1.3. The accessory detached dwelling unit does not exceed 1,200 square feet in size.
 - 1.4. The unit is on the same lot as the primary residence.
 - 1.5. The unit meets all apparatus access and water supply requirements of Chapter 5 and Appendix B of the 2022 California Fire Code.

Chapter 6 Section R602.10.4.3.1 and Table R602.10.3 (3) footnote "i" are new sections added to read as follows, based upon the express finding of necessity set forth in section 9.B.3. of this Ordinance.

Amend Section R328.7 to read as follows:

R328.7 Fire detection. Rooms and areas within dwelling units, basements and attached garages in which ESS are installed shall be protected by smoke alarms in accordance with Section R314. A heat detector, listed and interconnected to the smoke alarms, shall be installed in locations within dwelling units and attached garages where smoke alarms cannot be installed based on their listing.

ESS installed in Group R-3 and townhomes shall comply with the following:

1. Rooms and areas within dwellings units, sleeping units, basements and attached garages in which ESS are installed shall be protected by smoke alarms in accordance with Section R314.
2. A listed heat alarm interconnected to the smoke alarms shall be installed in locations within dwelling units, sleeping units, and attached garages where smoke alarms cannot be installed based on their listing.

Exceptions:

1. A listed heat detector may be used in place of a heat alarm, so long as it is interconnected with devices that provide an audible alarm at all sleeping areas.
2. A fire sprinkler associated with an approved automatic sprinkler system that triggers an audible alarm upon activation of the waterflow switch, may be used in place of a heat alarm.

Add a new subsection R602.10.4.3.1 to read as follows:

R602.10.4.3.1 Limits on methods GB and PCP. In Seismic Design Categories D0, D1, and D2, Method GB is not permitted for use as intermittent braced wall panels, but gypsum board is permitted to be installed when required by this Section to be placed on the opposite side of the studs from other types of braced wall panel sheathing. In Seismic Design Categories D0, D1, and D2, the use of Method PCP is limited to accessory structures.

Add a new footnote "i" to the end of CRC Table R602.10.3(3), after the five footnotes (a) – (f) currently shown, to read:

g. In Seismic Design Categories D0, D1, and D2, Method GB is not permitted, and the use of Method PCP is limited to accessory structures.

C. Only the following Appendix Chapters from the California Residential Code are adopted:

1. Appendix H, Patio Covers

Section 12.10.030 Correction of Violations.

The issuance or granting of a permit or approval of plans under this Title shall not prevent the Administrative Authority from thereafter requiring the correction of errors in such plans and specifications, or from preventing construction operations being carried on thereunder when in violation of this Code or of any other law, or from revoking any certificate of approval when issued in error.

- A. The 2022 California Residential Code referred to in Section 12.10.010 is adopted, together with Chapter 1 of the 2022 California Residential Code, with the following amendments and certain Appendix Chapters as follows:

Chapter 1, Division II, Section 105.5 is deleted and replaced to read as follows, as an administrative clarification, and does not modify a building standard pursuant to California Health & Safety Code Sections 17958, 17958.7 and/or 18941.5 This amendment establishes administrative standards for the effective enforcement of the building standards in the City of Los Altos.

Expiration. Every permit issued shall become invalid unless the work on the site authorized by such permit is commenced within 12 months after its issuance, or if the work authorized on the site by such permit is suspended or abandoned for a period of 12 months after the time the work is commenced. The building official is authorized to grant, in writing, one or more extensions of time for periods not more than 180 days each.

Before such work can be recommenced, a new permit shall be first obtained, and the fee therefore shall be one-half (1/2) the amount required for a new permit for such work provided no changes have been made, or will be made, in the original plans and specifications for such work; and provided, further, that such a suspension or abandonment has not exceeded one year. In order to renew action on a permit after one year expiration, the permittee shall be required to pay original full building permit fees.

For the purpose of this section, failure to progress a project to the next level of required inspection shall be deemed abandonment of the project.

For those projects that are residential only, the Building Official may modify expired permit fees when the owner can demonstrate that the project has received all required inspections, except for the Building Division final. The fee amount of one hundred dollars (\$100) shall be required within 10 working days of notice and the project shall achieve a final inspection within 30 days of

payment received, otherwise expired permit fees as noted above shall be required.

- B. Work commencing before permit issuance. Whenever any work for which a permit is required by the California Code of Regulations as adopted in this chapter has been commenced without first obtaining said permit, the building official shall charge a minimum of two times and/or up to four times, for repeat offenders, on all applicable plan review and permit (inspection) fees related to the required permit(s), including, but not limited to, building permits (including, but not limited to electrical, fire, mechanical and plumbing), sign permits and demolition permits. The legal registered owner of said property shall obtain a building permit within 30 days of any violation letter or stop-work notice issued by the City of Los Altos. The payment of the increased fee(s) shall not relieve any person from fully complying with the requirements of this code, other codes adopted by the city, or the requirements of the zoning ordinance. Failure to comply with the provisions of this chapter may also subject the violator to any other penalties, sanctions or remedies provided elsewhere in this code. This provision shall not apply to emergency work when the administration authority determines that such work was urgently necessary and that it was not practical to obtain a permit therefore prior to the commencement of such work. In such cases, a permit shall be obtained as soon as it is practical to do so; and if there is an unreasonable delay (exceeding two working days) in obtaining such permit, a fee as provided in this section shall be charged.

Once building permits are issued pursuant to work commenced without required permits; it is the responsibility of the permit holder to obtain their first required building inspection within 30 days from permit issuance date and shall receive a project final inspection within a one-year period. Any further delays will require additional building permit fees charged again in the original amount with an additional 30-day extension. If the project continues past this deadline to obtain a required building inspection, Administration Citation Fees and/or other legal remedies allowed by local, or state law shall be imposed.

Failure to contact the Building Division within five business days of receiving the violation notice may result in Administration Citation Fees, Chapter 1.30 of the Los Altos Municipal Code.

Section 12.10.040 Fee Refunds.

The Building Official may authorize refunding of any fee paid hereunder which was erroneously paid or collected.

The Building Official may authorize refunding of not more than 80 percent of the permit fee paid when no work has been done under a permit issued in accordance with this code.

The Building Official may authorize refunding of not more than 80 percent of the plan review fee paid when an application for a permit for which a plan review fee has been paid is withdrawn or canceled before any plan reviewing is done.

The Building Official shall not authorize refunding of any fee paid except on written application filed by the original permittee not later than 180 days after the date of fee payment.

SECTION 9. AUTHORITY AND FINDINGS.

- A. This Ordinance is enacted pursuant to and in compliance with Health and Safety Code Section 18941.5 and as expressly permitted in Government Code Section 50022.2.
- B. Express Findings as required by Health and Safety Code 18941.5(c). The City Council of the City of Los Altos hereby expressly finds that amendments to the California Residential Code adopted by this Ordinance and as described in section 12.10.010 are necessary for the protection of the public health, safety, and welfare, due to the local climatic, geological, or topographical conditions.
 - 1. Section R301.1.3.2. The City of Los Altos is geographically situated in Seismic Design Categories "D" and "E." The occurrence of a major earthquake would significantly impact all structures. Therefore, mitigation measures are necessary for residential two-story buildings and above. Engineered designed buildings over one-story in height will greatly reduce extensive damage during a substantial seismic event. The City of Los Altos is adjacent to several active earthquake faults capable of producing these events.
 - 2. Section R313.1 and R313.2. The City of Los Altos experiences low humidity, high winds and warm temperatures during the summer months creating conditions which are particularly conducive to the ignition and spread of grass, brush, and structure fires. Additionally, the City of Los Altos is geographically situated adjacent to active earthquake faults capable of producing substantial seismic events. Since the City of Los Altos is divided by creeks, an expressway and other substantial traffic corridors, the occurrence of a major earthquake would significantly impact the ability of fire crews to respond to emergencies should one or more bridges collapse or be substantially damaged. In addition, fire suppression capabilities would be severely limited should the water system be extensively damaged during

the seismic event. Therefore, mitigation measures are necessary such as: automatic fire suppression systems, communications systems, access to buildings, seismic protection, safety controls for hazardous materials and other safeguards in order to minimize the risks to citizens, firefighters and property due to the severity of the fire threat and potential response delays.

3. Section R602.10.4.3.1 and Table R602.10.3(3) footnote "i." The amendment addresses the problem of poor performance of gypsum wallboard and portland cement plaster as wall bracing materials in high seismic areas. The City of Los Altos is situated in a high seismic area. This amendment reflects the recommendations by the Structural Engineers Association of Southern California (SEAOSC) and the Los Angeles City Joint Task Force that investigated the poor performance of these bracing materials that were observed in 1994 Northridge earthquake.

SECTION 10. AMENDMENT OF CODE: Title 12, Chapter 12.12 of the Municipal Code is hereby repealed.

SECTION 11. AMENDMENT OF CODE: Title 12, Chapter 12.12 of the Municipal Code is hereby added to read as follows:

Chapter 12.12 PLUMBING CODE

Section 12.12.010 Plumbing Code – Adoption of the California Plumbing Code.

Section 12.12.020 Amendments.

Section 12.12.010 Plumbing Code – Adoption of the California Plumbing Code.

The 2022 California Plumbing Code, contained in California Code of Regulations, Title 24, Part 5, which incorporates and amends the Uniform Plumbing Code 2021 Edition, published by the International Association of Plumbing and Mechanical Officials, with amendments and certain appendices set forth in Section 12.12.020 is hereby adopted. There is one copy of said code on file in the office of the Building Official for use and examination by the public.

Section 12.12.020 Amendments.

The 2022 California Plumbing Code referred to in Section 12.12.010 is adopted with the following amendments and certain Appendix Chapters as follows:

- A. Section 710.1 is deleted and replaced to read as follows, based upon the finding

of express necessity set forth in Section 8.B.1 of this Ordinance.

B. Drainage of Fixtures Located Below the Next Upstream Manhole or Below the Main Sewer level.

710.1 Backflow Protection All new, replaced, or repaired building sewers, both public and private, requiring sewer connections to the City main sewer system shall be protected from backflow of sewage by installing an accessible approved type of backwater and atmospheric relief valve. Cleanouts for drains that pass through a backwater valve shall be clearly identified with a permanent label stating, "backwater valve downstream". Building sewers shall have an atmospheric relief valve installed upstream of the backwater valve outside the building in close proximity to the foundation.

Exception: Sewer repairs where there is no existing cleanout located at or near the building foundation, may have these atmospheric relief devices placed near the repair upstream of the newly installed backwater valve.

C. Chapter 12 Section 1211.8 is amended to read as follows, based upon express finding of necessity set forth in section 8.B.2 of this Ordinance.

1211.7 Earthquake-Actuated Gas Shutoff Valves Earthquake-actuated gas shutoff valves designed to automatically shut off the gas at the location of the valve in the event of a seismic disturbance and certified by the State Architect as conforming to California Code of Regulations, Title 24, Part 12, Chapter 12-16-1, shall be installed in all new buildings, and when reinstalling meters at the same location, and when relocating gas utility meters. Said gas shutoff valves shall be at or near the meter supplying gas to individual buildings.

D. Only the following Appendix Chapters from the Plumbing Code are adopted:

1. Appendix A, Recommended Rules for Sizing the Water Supply System.
2. Appendix B, Explanatory Notes on Combination Waste and Vent Systems.
3. Appendix D, Sizing Storm Water Drainage Systems.
4. Appendix H, Private Sewage Disposal Systems.
5. Appendix I, Installation Standard for Pex Tubing Systems for Hot and – Cold-Water Distribution.

SECTION 12. AUTHORITY AND FINDINGS.

- A. This Ordinance is enacted pursuant to and in compliance with Health and Safety Code Section 18941.5 and as expressly permitted in Government Code Section 50022.2.

B. Express Findings as required by Health and Safety Code 18941.5(c). The City Council of the City of Los Altos hereby expressly finds that amendments to the Plumbing Code adopted by this Ordinance and as described in section 12.12.020 are necessary for the protection of the public health, safety, and welfare, due to the local climatic, geologic, or topographical conditions.

1. Section 710.1 requires that fixtures installed on a floor level lower than the next upstream manhole cover of the public or private sewer, serving such drainage piping, shall be protected from backflow of sewage by installing an approved backwater valve. Due to the topography of the City of Los Altos, it shall be required to install an accessible approved type of backwater and atmospheric relief valve in all new, replaced or repaired public and private building sewers.
2. Local Geological Conditions – The City of Los Altos is located in a highly active seismic region. The need to incorporate this modification into the code will help to assure that all new buildings and relocated gas meters for existing buildings equipped with these automatic gas shut off devices are designed to minimize fire, life and safety issues arising from damage due to an earthquake.

SECTION 13. AMENDMENT OF CODE: Title 12, Chapter 12.16, of the Municipal Code is hereby repealed.

SECTION 14. AMENDMENT OF CODE: Title 12, Chapter 12.16, of the Municipal Code is hereby added to read as follows:

Chapter 12.16 MECHANICAL CODES

Section 12.16.010 Adoption of the California Mechanical Code.

The 2022 California Mechanical Code, contained in the 2022 California Code of Regulations, Title 24, Part 4, which incorporates and amends the Uniform Mechanical Code 2021 Edition, published by the International Association of Plumbing and Mechanical Officials, is hereby adopted. There is one copy of said code on file in the office of the Building Official for use and examination by the public.

SECTION 15. AMENDMENT OF CODE: Title 12, Chapter 12.20, of the Municipal Code is hereby repealed.

SECTION 16. AMENDMENT OF CODE: Title 12, Chapter 12.20, of the Municipal

Code is hereby added to read as follows:

Chapter 12.20 ELECTRICAL CODE

Section 12.20.010 Adoption of the California Electrical Code.

The 2022 California Electrical Code, contained in the 2022 California Code of Regulations, Title 24, Part 3, incorporates and amends the National Electrical Code 2020 Edition, published by the National Fire Protection Association, is hereby adopted. There is one copy of said code on file in the office of the Building Official for use and examination by the public.

SECTION 17. AMENDMENT OF CODE: Title 12, Chapter 12.22, of the Municipal Code is hereby repealed.

SECTION 18. AMENDMENT OF CODE: Title 12, Chapter 12.22 of the Municipal Code is hereby added to read as follows:

Chapter 12.22 ENERGY CODE

12.22.010 Adoption of the California Energy Code.

There is hereby adopted by reference as if fully set forth herein, the 2019 California Energy Code, contained in the California Code of Regulations, Title 24, Part 6, published by the International Code Council, and each and all of its regulations and provisions. One copy is on file for use and examination by the public in the office of the building official.

12.22.020 Amendments for all-electric buildings.

City of Los Altos local amendments to the 2022 California Energy Code. Upon adoption of this Code in the event that there is any conflict between local amendments and the 2022 California Energy Code the most restrictive shall prevail.

- A. Amend Section 100.1(b) of the Energy Code by adding the following definitions to read as follows:

ALL-ELECTRIC BUILDING is a building that has no natural gas or propane plumbing installed within the building.

NEWLY CONSTRUCTED BUILDING (Applicable to Chapter 12.22 Energy

Code Section 12.22.020 Amendments) is a building that has never been used or occupied for any purpose and supported by 1) a new structural foundation, 2) an existing, structural foundation where a building has been demolished and removed to floor or below, or 3) a combination of 1) and 2).

PUBLIC BUILDING is a building used by the public for any purpose, such as assembly, education, entertainment, or worship.

SCIENTIFIC LABORATORY BUILDING is a building or area where research, experiments, and measurement in medical, life, and physical sciences are performed and/or stored requiring examination of fine details. The building may include workbenches, countertops, scientific instruments, and supporting offices.

Subchapter 1 Section 100.0(e)2.A. is deleted and replaced to read as follows, based on express finding of necessity set forth of this Ordinance.

B. Amend Section 100.0(e)2.A. of the Energy Code to read as follows:

2. Newly constructed buildings.

A. Sections 110.0 through 110.12 apply to all newly constructed buildings within the scope of Section 100.0(a). In addition, newly constructed buildings shall meet the requirements of Subsections B, C, D or E, as applicable and shall be an all-electric building as defined in Section 100.1(b).

Exception 1: Residential Single-Family Dwellings, Detached ADUs (Accessory Dwelling Units), Multifamily Dwellings with two to nine units may install non-electric (natural gas-fueled) cooking and fireplace appliances if the applicant complies with the prewiring provisions, Subsection 12.22.020B.3.

Exception 2: Non-residential Buildings containing for-profit restaurant open to the public may install gas-fueled cooking appliances. The applicant shall comply with the pre-wiring provision of Subsection 12.22.020B.3.

Exception 3: Non-residential buildings, Scientific Laboratory Buildings and Public Buildings may apply to the Building Division of the Los Altos Development Services Department for an exception to install a non-electric fueled appliance or piece of equipment. The Building Division of the Los Altos Development Services Department shall grant an exception if they find

the following conditions are met:

- i. The applicant shows that there is a public or business-related need that cannot be reasonably met with an electric fueled appliance or piece of equipment.
- ii. The applicant complies with the pre-wiring provisions to the non-electric appliance or piece of equipment noted at Subsection 12.22.020B.3.

The decision of the Building Division of the Los Altos Development Services Department shall be final unless the applicant appeals the decision to the City Manager or his or her designee within 15 days of the date of the decision. The City Manager's or his or her designee's decision on the appeal shall be final.

3. Wiring to accommodate future electric appliances or equipment.

- (a) If a non-electric appliance or piece of equipment is allowed to be installed, the appliance or equipment location must also be electrically pre-wired for future electric appliance or equipment installation, including:
 - i. A dedicated circuit, phased appropriately, with a minimum amperage requirement for a comparable electric appliance with an electrical receptacle or junction box that is connected to the electric panel with conductors of adequate capacity, extending to within 3 feet of the appliance and accessible with no obstructions. Appropriately sized conduit may be installed in lieu of conductors; and
 - ii. Both ends of the unused conductor or conduit shall be labeled with the words "For Future Electric appliance or equipment" and be electrically isolated; and
 - iii. A reserved circuit breaker space shall be installed in the electrical panel adjacent to the circuit breaker for the branch circuit and labeled for each circuit, an example is as follows (i.e. "For Future Electric Range;"); and
 - iv. All electrical components, including conductors, receptacles, junction boxes, or blank covers, related to this section shall be installed in accordance with the California Electrical Code.

SECTION 19. AUTHORITY AND FINDINGS.

The following findings support that the above amendments and modifications are reasonably necessary because of local climatic, geological, or topographical conditions:

The City of Los Altos is located in Climate Zone 4 as established in the 2019 California Energy Code. Climate Zone 4 includes Santa Clara County, San Benito County, portions of Monterey County and San Luis Obispo. The City experiences an average of 19 inches of precipitation per year. In Los Altos, January is the rainiest month of the year while July is the driest month of the year. Temperatures average about 80 degrees Fahrenheit in the summer and about 40 degrees Fahrenheit in the winter. These climatic conditions along with the effects of climate change caused by Green House Gas (GHG) emissions generated from burning natural gas to heat buildings and emissions from Vehicle Miles Traveled results in an overall increase in global average temperature. Higher global temperatures are contributing to rising sea levels, record heat waves, droughts, wildfires, and floods.

The above local amendments to the 2022 California Energy Code are necessary to combat the ever-increasing harmful effects of global climate change. Implementation of the proposed code amendments will achieve decarbonization and provide an accelerated path to reduce GHG emissions. The proposed Ordinance containing these amendments would ensure that new buildings use cleaner sources of energy which helps meet the goal of cutting carbon emissions in half by 2030.

All-electric building design benefits the health, welfare, and resiliency of Los Altos and its residents.

SECTION 20. AMENDMENT OF CODE: Title 12, Chapter 12.24 of the Municipal Code is hereby repealed.

SECTION 21. AMENDMENT OF CODE: Title 12, Chapter 12.24 of the Municipal Code is hereby added to read as follows:

Chapter 12.24 FIRE CODE

Section 12.24.010 Adoption of the 2022 California Fire Code

Section 12.24.015 Findings.

Section 12.24.020 Establishment and duties of the fire prevention division.

Section 12.24.030 Definitions.

Section 12.24.080 Fire Code Amendments.

Section 12.24.010 Adoption of the 2022 California Fire Code

There is hereby adopted by the City, for the purpose of prescribing regulations

governing conditions hazardous to life and property from fire or explosion, that certain code known as the 2022 California Fire Code, contained in the 2022 California Code of Regulations, Title 24, Part 9, which incorporates and amends the International Fire Code 2021 Edition, published by the International Code Council, including Appendix Chapters B, C, D and O, save and except such portions as are hereinafter deleted, modified or amended by this chapter. One copy has been filed for use and examination by the public in the office of the Building Official. Said codes are adopted and incorporated as fully as if set out at length herein, and from the date on which the ordinance codified in this chapter shall take effect.

Section 12.24.015 Findings.

The City Council of the City of Los Altos hereby expressly finds that amendments to the California Fire Code adopted by this chapter and commencing with Section 12.24.080 are reasonably necessary for the protection of the public health, safety, and welfare, due to the local climatic, geologic, or topographical conditions specified as follows:

The City of Los Altos experiences low humidity, high winds and warm temperatures during the summer months creating conditions which are particularly conducive to the ignition and spread of grass, brush, and structure fires. Additionally, the City of Los Altos is geographically situated adjacent to active earthquake faults capable of producing substantial seismic events. Since the City of Los Altos is divided by creeks, an expressway and other substantial traffic corridors, the occurrence of a major earthquake would significantly impact the ability of fire crews to respond to emergencies should one or more bridges collapse or be substantially damaged. In addition, fire suppression capabilities would be severely limited should the water system be extensively damaged during the seismic event. Therefore, mitigation measures are necessary such as: automatic fire suppression systems, communications systems, access to buildings, seismic protection, safety controls for hazardous materials and other safeguards in order to minimize the risks to citizens, firefighters and property due to the severity of the fire threat and potential response delays.

The below table provides the express findings and determinations (where necessary pursuant to California Health & Safety Code Sections 17958, 17958.7 and/or 18941.5) justifying the City of Los Altos' amendments to the 2022 Edition of the California Fire Code as reasonably necessary because of local climatic, geologic, or topographic conditions.

Admin = This amendment is necessary for administrative clarification and does not modify a building standard pursuant to California Health & Safety Code Sections 17958, 17958.7 and/or 18941.5. This amendment establishes administrative standards for the effective enforcement of the building standards in the City of Los

Altos.

I = This amendment is reasonably necessary because of climatic conditions.

II = This amendment is reasonably necessary because of topographical conditions.

III = This amendment is reasonably necessary because of geological conditions.

Code Section	California Fire Code Local Amendmer	Findings
108.5	Final Inspection	Admin
112.4	Violation penalties	Admin
Chapter 2	Definitions	Admin
503.1	Where required	Admin
503.1.1	Buildings and facilities	Admin
503.2.1	Dimensions	Admin
503.2.4	Turning Radius	Admin
503.2.7	Grade	Admin
503.5	Required Gates or Barricades	Admin
503.6	Security Gates	Admin
504.5	Access control devices	II & III
505.1	Address identification	Admin
510.1	Emergency responder communication coverage in new buildings	Admin
510.1.1	Obstruction by new buildings	Admin
510.3	Permit required	Admin
510.4	Technical requirements	Admin
510.4.1.1	Minimum signal strength into the building	Admin
510.4.1.2	Minimum signal strength out of the building	Admin
510.5	Installation requirement	Admin
510.5.1	Approval prior to installation	Admin
510.5.3	Acceptance test procedure	Admin
603.11	Immersion Heaters	Admin
605.5	Portable unvented heaters	Admin
605.5.2.1.1	Prohibited locations	Admin
703.3	Fire-resistant penetrations and joints	Admin
901.6.2	Integrated testing	Admin
901.6.2.1	High-rise buildings	Admin
901.6.3	Records	Admin
903.2	Where required	II & III

909.20.1	Schedule	Admin
1202.1	Definitions	Admin
1207.1.5	Large-scale fire test	Admin
1207.2.2.1	Ongoing inspection and testing	Admin
1207.5.2	Maximum allowable quantities	Admin
1207.5.5	Fire suppression systems	III
1207.11.3	Location	Admin
1207.11.6	Fire detection	III
3305.5	Fire watch	Admin
3305.10	Fire Walls	II & III
3311.1.1	Fire Department Access Roadways	II & III
3312.1	Stairways required	Admin
3312.4	Required Means of Egress	II & III
3315.1	Completion before occupancy	Admin
4901.3	Where applicable	Admin
4901.4	Exemptions	Admin
4906.1.1	Hazardous vegetation and fuels mgmt..	Admin
4906.1.2	Maintenance required	Admin
4906.1.3	4906.1.3 Additional measures	Admin
4906.1.4	Exemption	Admin
4907.3	Requirements	Admin
5001.2.2.2	Health Hazards	Admin
5002.1	Definitions	Admin
5003.1.3.1	Toxic, Highly Toxic, Moderately Toxic Gases	III
5003.1.5	Health Hazards - Other	III
5003.1.6	Additional Spill Control and Secondary Containment Requirements	III
5003.2.2.1	Design and Construction	III
5003.2.2.2	Additional Regulation for Supply Piping for Health Hazard Materials	III
5003.5.2	Ventilation Ducting	III
5003.5.3	"H" Occupancies	III
5003.10.4.x.x	Elevators utilized to transport hazardous materials	Admin
5004.2.1	Spill Control for Hazardous Material Liquids	Admin
5004.2.2.2	Incompatible Materials	Admin
5402.1	Definition	Admin
5601.1.1.3	Fireworks	Admin

5704.2.7.5.8	Overfill Prevention	Admin
5704.2.7.5.9	Automatic Filling of Tanks	Admin
5704.2.9.6.1	Locations where above-ground tanks are prohibited	Admin
5706.2.4.4	Locations where above-ground tanks are prohibited	Admin
5707.3.3	Site plan	Admin
5809.3.4	Site plan	Admin
6104.2	Maximum capacity within established limits	Admin
6001.1	Scope	Admin
6004.1	General	Admin
6004.1.1	Special limitations for indoor storage and use by occupancy	Admin
6004.1.1.1	Group A, E, I or U occupancies	Admin
6004.1.1.2	Group R occupancies	Admin
6004.1.1.3	Offices, retail sales and classrooms	Admin
6004.2	Indoor storage and use	Admin
6004.2.1	Applicability	Admin
6004.2.1.4	Quantities exceeding the minimum threshold	Admin
6004.4	General indoor requirements	Admin
6004.4.1	Cylinder and tank location	Admin
6004.4.2	Ventilated areas	Admin
6004.4.3	Piping and controls	Admin
6004.4.4	Gas rooms	Admin
6004.4.5	Treatment systems	Admin
6004.4.5.1	Design	Admin
6004.4.5.2	Performance	Admin
6004.4.5.3	Sizing	Admin
6004.4.5.4	Stationary tanks	Admin
6004.4.5.5	Portable tanks and cylinders	Admin
6004.4.6	Emergency power	Admin
6004.4.6.1	Fail-safe systems	Admin
6004.4.7	Automatic fire detection system	Admin
6004.4.8	Gas detection system	Admin
6004.4.8.1	Alarms	Admin
6004.4.8.2	Shut off of gas supply	Admin
6104.2	Maximum capacity within established	Admin

	limits	
6405.3.1	Silane distribution systems automatic shutdown	Admin

Section 12.24.020 Establishment and duties of the fire prevention division.

- a. The California Fire Code shall be enforced by the Santa Clara County Fire Department which shall be operated under the supervision of the Chief of the Fire Department.
- b. The City fire marshal shall be the chief of the fire prevention division and shall be appointed by the Chief of the Fire Department.
- c. The Chief of the Fire Department may assign members of the fire department as deputy fire marshals as shall be necessary.

Section 12.24.030 Definitions.

- a. Wherever the words "board of appeal" are used, they shall mean the City Council of the City of Los Altos, or the body appointed by the Council to pass on matters pertaining to fire safety.
- b. Wherever the words "fire prevention bureau" are used in the California Fire Code, they shall mean the fire prevention division of the fire department.
- c. Wherever the term "fire code official" is used, it shall mean the chief of the fire department.
- d. Wherever the word "jurisdiction" is used in the California Fire Code, it shall mean the City of Los Altos.

Section 12.24.080 Fire Code Amendments

The 2022 California Fire Code referred to in Section 12.24.010 is adopted with the following amendments and certain Appendix Chapters as follows:

Chapter 1 SCOPE AND ADMINISTRATION

Section 105 PERMITS

Section 108.5 Final inspection.

Section 112.4 Violation penalties.

Section 108 INSPECTIONS

Section 108.5 is added to read as follows:

Section 108.5 Final Inspection.

No final inspection as to all or any portion of a development shall be deemed completed until the installation of the required fire protection facilities and access ways have been completed and approved. No final certificate of occupancy may be granted until the Fire Department issues notice of final clearance of such fire protection facilities and access ways to the Building Division.

Section 112 VIOLATIONS

Section 112.4 is amended to read as follows:

Section 112.4 Violation penalties.

Violation penalties shall be in accordance with Title 1, Chapter 1.30 of the City of Los Altos Municipal Code.

Chapter 2 DEFINITIONS

Chapter 2 of the 2022 California Fire Code and 2021 International Fire Code is amended to include the following definitions:

CORROSIVE LIQUID. Corrosive liquid is:

1. any liquid which, when in contact with living tissue, will cause destruction or irreversible alteration of such tissue by chemical action; or
2. any liquid having a pH of 2 or less or 12.5 or more; or
3. any liquid classified as corrosive by the U.S. Department of Transportation; or
4. any material exhibiting the characteristics of corrosivity in accordance with Title 22, California Code of Regulations §66261.22.

LARGE-SCALE FIRE TESTING. Testing a representative energy storage system that induces a significant fire into the device under test and evaluates whether the fire will spread to adjacent energy storage system units, surrounding equipment, or through an adjacent fire-resistance-rated barrier.

MODERATELY TOXIC GAS. A chemical or substance that has a median lethal concentration (LC50) in air more than 2000 parts per million but not more than 5000 parts per million by volume of gas or vapor, when administered by continuous inhalation for an hour, or less if death occurs within one hour, to albino rats weighing between 200 and 300 grams each.

HEALTH HAZARD – OTHER. A hazardous material which affects target organs of the body, including but not limited to, those materials which produce liver damage, kidney damage, damage to the nervous system, act on the blood to decrease hemoglobin function, deprive the body tissue of oxygen or affect reproductive capabilities, including mutations (chromosomal damage), sensitizers or teratogens (effect on fetuses).

SPILL CONTROL. That level of containment that is external to and separate from the primary containment and is capable of safely and securely containing the contents of the largest container and prevents the materials from spreading to other parts of the room.

SECONDARY CONTAINMENT. Secondary containment is that level of containment that is external to and separate from primary containment and is capable of safely and securely containing the material, without discharge, for a period of time reasonably necessary to ensure detection and remedy of the primary containment failure.

WORKSTATION. A defined space or an independent principal piece of equipment using flammable or unstable (Class 3 or 4 as ranked by NFPA 704) hazardous materials where a specific function, laboratory procedure or research activity occurs. Approved or listed hazardous materials storage cabinets, flammable liquid storage cabinets or gas cabinets serving a workstation are included as part of the workstation. A workstation is allowed to contain ventilation equipment, fire protection devices, detection devices, electrical devices and other processing and scientific equipment.

Chapter 5 FIRE SERVICE FEATURES

Section 503 FIRE APPARATUS ACCESS ROADS

Section 503.1 Where required.

Section 503.1.1 Buildings and facilities.

Section 503.2.1 Dimensions.

Section 503.2.4 Turning Radius

Section 503.2.7 Grade

Section 503.5 Required Gates or Barricades

Section 503.6 Security Gates

Section 503.1 is amended to read as follows:

Section 503.1 Where required. Fire apparatus access roads shall be provided and maintained in accordance with Sections 503.1.1 through 503.1.3 and as per Fire Department access road Standards.

Section 503.1.1 is amended to read as follows:

503.1.1 Buildings and facilities. Approved fire apparatus access roads shall be provided for every facility, building or portion of a building hereafter constructed or moved into or within the jurisdiction. The fire apparatus access road shall comply with the requirements for this section and shall extend to within 150 feet (45 720 mm) of all portions of the facility and all portions of the exterior walls of the first story of the building as measured by an approved route around the exterior of the building or facility.

Exceptions:

1. In other than R-3 or U occupancies, when the building is equipped throughout with an approved automatic sprinkler system, installed in accordance with Section 903.3.1.1 the dimension may be increased to a maximum of 300 feet when approved by the fire code official.
2. When there are not more than two Group R-3 or accessory Group U occupancies, the dimension may be increased to a maximum of 200 feet.
3. When apparatus roads cannot be installed because of topography, waterways, nonnegotiable grades or other similar conditions, an approved alternative means of fire protection shall be provided.

Section 503.2.1 is amended to read as follows:

Section 503.2.1 Dimensions. Fire apparatus access roads shall have an unobstructed width of not less than 20 feet (6096 mm) for engines, and 26 feet (7925 mm) for aerial fire apparatus exclusive of shoulders, except for approved gates or barricades in accordance with Sections 503.5.1 and 503.6. and the unobstructed vertical clearance shall be a minimum of 13 feet 6 inches (4115 mm), or as determined by the fire code official.

Exception: When there are not more than two Group R, Division 3, or Group U parcels, the access road width may be modified by the fire code official.

Section 503.2.4 is amended to read as follows:

503.2.4 Turning radius. The required turning radius of a fire apparatus access road shall be a minimum of 30 feet (9144 mm) inside, and a minimum of 50 feet (15240 mm) outside.

Section 503.2.7 is amended to read as follows:

503.2.7 Grade. The maximum grade of a fire department apparatus access road shall not exceed 15-percent, unless approved by the fire code official.

Section 503.5 is amended to read as follows:

503.5 Required gates or barricades. The fire code official is authorized to require the installation and maintenance of gates or other approved barricades across fire apparatus access roads, trails, or other accessways, not including the public streets, alleys, or highways. The minimum width for commercial applications is 20 feet (6096 mm), and 12 feet (4268 mm) for single-family dwellings. Electric gate operators, where provided shall be listed in accordance with UL 325. Gates intended for automatic operation shall be designed, constructed, and installed to comply with the requirements of ASTM F2200.

Section 503.6 is amended to read as follows:

503.6 Security gates. The installation of security gates across a fire apparatus access road shall be approved by the fire code official. Where security gates are installed, they shall have an approved means of emergency operation. The security gates and the emergency operation shall be maintained operational at all times. Electric gate operators, where provided, shall be listed in accordance with UL 325. Gates intended for automatic operation shall be designed, constructed and installed to comply with the requirements of ASTM F2200. The minimum width for commercial applications is 20 feet (6096 mm), and 12 feet (4268 mm) for single-family dwellings.

Section 504 ACCESS TO BUILDINGS AND ROOFS

Section 504.5 is added to read as follows:

Section 504.5 Access control devices. When access control devices including bars, grates, gates, electric or magnetic locks or similar devices, which would inhibit rapid fire department emergency access to the building, are installed, such devices shall be approved by the fire code official. All electrically powered access control devices shall be provided with an approved means for deactivation or unlocking from a single location or otherwise approved by the fire code official.

Access control devices shall also comply with Chapter 10 Means of Egress.

Section 505 PREMISES IDENTIFICATION

Section 505.1 is amended to read as follows:

505.1 Address identification. New and existing buildings shall be provided with

approved address identification. The address identification shall be legible and placed in a position that is visible from the street or road fronting the property. Address identification characters shall contrast with their background. Address numbers shall be Arabic numbers or alphabetical letters. Numbers shall not be spelled out. Each character shall be not less than 6 inches (153 mm) high with a minimum stroke width of 1/2 inch (12.7 mm). Where required by the fire code official, address identification shall be provided in additional approved locations to facilitate emergency response. Where access is by means of a private road and the building cannot be viewed from the public way, a monument, pole or other sign or means shall be used to identify the structure. Address identification shall be maintained.

The following is a guideline for adequate address number dimensions:

- a. The number posted up to 49 feet from the public street shall be of one solid color which is contrasting to the background and be at least six (6) inches high with a half (1/2) inch stroke.
- b. The number posted from 50 to 100 feet from the public street shall be of one solid color which is contrasting to the background and be at least six (6) inches high with a one (1) inch stroke.
- c. The number posted over 100 to 199 feet from the public street shall be of one solid color which is contrasting to the background and be at least ten (10) inches high with a one and a half (1 1/2) inch stroke.
- d. The number posted over 200 to 299 feet from the public street shall be of one solid color which is contrasting to the background and be at least ten (18) inches high with a one and a half (2) inch stroke.
- e. The number posted over 300 to 400 feet from the public street shall be of one solid color which is contrasting to the background and be at least ten (24) inches high with a one and a half (2 1/2) inch stroke.

Section 510 EMERGENCY RESPONDER COMMUNICATION COVERAGE

Section 510.1 is amended to read as follows:

510.1 Emergency responder radio coverage in new buildings. Approved radio coverage for emergency responders shall be provided within all buildings meeting any one of the following conditions:

1. There are more than 3 stories above grade plane (as defined by the California Building Code Section 202);
2. The total building area is 30,000 square feet or more;
3. The total basement area is 5,000 square feet or more;
4. Where required by the fire code official and radio coverage signal strength levels are not consistent with the minimum levels set forth in Section 510.4.1

Exceptions:

1. Where approved by the fire code official, a wired communication system in accordance with Section 907.2.12.2 shall be permitted to be installed or maintained in lieu of an approved radio coverage system.
2. Where it is determined by the fire code official that the radio coverage system is not needed.
3. In facilities where emergency responder radio coverage is required and such systems, components or equipment required could have a negative impact on the normal operations of that facility, the fire code official shall have the authority to accept an automatically activated emergency responder radio coverage system.
4. Buildings and areas of buildings that have minimum radio coverage signal strength levels of the Silicon Valley Regional Interoperability Authority (SVRIA) P25 Phase 2 700 MHz Digital Trunked Radio System within the building in accordance with Section 510.4.1 without the use of an indoor radio coverage system.

The radio coverage system shall be installed and maintained in accordance with Sections 510.4 through 510.6.4 of this code and with the applicable provisions of NFPA 1221, Standard for the Installation, Maintenance and Use of Emergency Services Communications Systems.

The coverage shall be based upon the existing coverage levels of the public safety communication systems of the jurisdiction at the exterior of the building. This section shall not require improvement of the existing public safety communication systems.

Section 510.1.1 is amended to read as follows:

510.1.1 Obstruction by new buildings. No obstruction of the public safety system backhaul shall be allowed without an approved mitigating plan.

Section 510.3 is amended to read as follows:

510.3 Permit required. A construction permit, for the installation of, or modification of, emergency responder radio coverage systems and related equipment is required as specified in Section 105.7.6. Maintenance performed in accordance with this code is not considered a modification and does not require a permit. A frequency change made to an existing system is considered to be new construction and will require a construction permit

Section 510.4 is amended to read as follows:

510.4 Technical requirements. Systems, components, and equipment required to provide the emergency responder radio coverage system shall comply with the

current Emergency Responders Radio Coverage Systems Standard Details & Specification enforced by the Santa Clara County Fire Department.

Section 510.4.1.1 is amended to read as follows:

510.4.1.1 Minimum signal strength into the building. The minimum inbound signal strength shall be sufficient to provide usable voice communications throughout the coverage area as specified by the fire code official. The inbound signal level shall be sufficient to provide not less than a Delivered Audio Quality (DAQ) of 3.0 for analog communications and DAQ of 3.4 for digital communications systems or an equivalent Signal-to-Interference-Plus-Noise Ratio (SINR) applicable to the technology.

Section 510.4.1.2 is amended to read as follows:

510.4.1.2 Minimum signal strength out of the building. The minimum outbound signal strength shall be sufficient to provide usable voice communications throughout the coverage area as specified by the fire code official. The outbound signal level shall be sufficient to provide not less than a DAQ of 3.0 for analog communications and DAQ of 3.4 for digital communications systems or an equivalent SINR applicable to the technology.

Section 510.5 is amended to read as follows:

510.5 Installation requirement. The installation of the emergency responder radio coverage system shall be in accordance with NFPA 1221 and the current Emergency Responder Radio Coverage Systems Standard Details & Specification enforced by the Santa Clara County Fire Department.

Section 510.5.1 is amended to read as follows:

510.5.2 Approval prior to installation. Amplification systems capable of operating on frequencies licensed to any public safety agency by the FCC or other radio licensing authority shall not be installed without prior coordination and approval of the fire code official and the agency FCC license holder or systems administrator.

The first paragraph of Section 510.5.3 is amended to read as follows:

510.5.3 Acceptance test procedure. Where an emergency responder radio coverage system is required, and upon completion of installation, the building owner shall have the radio system tested to verify that two-way coverage on each floor of the building is not less than 95 percent. Final system acceptance will require ERRCS

power level and DAQ testing with agency FCC license holder, systems administrators, or designee.

Chapter 6 BUILDING SERVICES AND SYSTEMS

Section 603 ELECTRICAL EQUIPMENT, WIRING AND HAZARDS

Add Section 603.11 to read as follows:

603.11 Immersion Heaters. All electrical immersion heaters used in dip tanks, sinks, vats, and similar operations shall be provided with approved over-temperature controls and low liquid level electrical disconnects. Manual reset of required protection devices shall be provided.

Section 605 FUEL-FIRED APPLIANCES

Section 605 is amended to read as follows:

605.5 Portable unvented heaters. Portable unvented fuel-fired heating equipment shall be prohibited in occupancies in Groups A, B, E, I, R-1, R-2, R2.1, R2.2, R-3, R3.1 and R-4 and ambulatory care facilities. Portable unvented fuel-fired heating equipment shall be prohibited in the public rights-of-way.

Exceptions:

1. Portable unvented fuel-fired heaters listed in accordance with UL 647 are permitted to be used in one and two-family dwellings, where operated and maintained in accordance with the manufacturer's instructions.
2. Portable outdoor gas-fired heating appliances in accordance with Section 605.5.2.

Section 605.5.2.1.1 is amended to read as follows and the exception in the Section is deleted:

605.5.2.1.1 Prohibited locations. The storage or use of portable outdoor gas-fired heating appliances is prohibited in any of the following locations:

1. Inside of any occupancy where connected to the fuel gas container.
2. Inside of tents, canopies, and membrane structures.
3. On exterior balconies and rooftops

Chapter 7 FIRE AND SMOKE PROTECTION FEATURES

Section 703 PENETRATIONS

Section 703.3 is amended to read as follows:

703.3 Fire-resistant penetrations and joints. In high-rise buildings, in buildings assigned to Risk Category III or IV, or in fire areas containing Group R occupancies with an occupant load greater than 100, and other occupancies as determined necessary special inspections for through-penetrations, membrane penetration firestops, fire resistant joint systems and perimeter fire containment systems that are tested and listed in accordance with CBC Sections 714.4.1.2, 714.5.1.2, 715.3.1 and 715.4 shall be in accordance with Section 1705.18.1 or 1705.18.2.

Chapter 9 FIRE PROTECTION AND LIFE SAFETY SYSTEMS

Section 901 GENERAL

Section 901.6.2 is amended as follows:

901.6.2 Integrated testing. Where two or more fire protection or life safety systems are interconnected, the intended response of subordinate fire protection and life safety systems shall be verified when required testing of the initiating system is conducted. In addition, integrated testing shall be performed in accordance with Sections 901.6.2.1 and 901.6.2.2.

901.6.2.1 High-rise buildings. For high-rise buildings, integrated testing shall comply with NFPA 4, with an integrated test performed prior to issuance of the certificate of occupancy and at intervals not exceeding 10 years, unless otherwise specified by an integrated system test plan prepared in accordance with NFPA 4. If an equipment failure is detected during integrated testing, a repeat of the integrated test shall not be required, except as necessary to verify operation of fire protection or life safety functions that are initiated by equipment that was repaired or replaced. For existing buildings, the testing timeframe shall be specified by the integrated systems test plan prepared in accordance with NFPA 4 as approved by the fire code official.

901.6.2.2 Smoke control systems. Where a fire alarm system is integrated with a smoke control system as outlined in Section 909, integrated testing shall comply with NFPA 4, with an integrated test performed prior to issuance of the certificate of occupancy and at intervals not exceeding 10 years, unless otherwise specified by an integrated system test plan prepared in accordance with NFPA 4. If an equipment failure is detected during integrated testing, a repeat of the integrated test shall not be required, except as necessary to verify operation of fire protection or life safety functions that are initiated by equipment that was repaired or replaced. For existing buildings, the testing timeframe shall be specified by the integrated systems test plan prepared in accordance with NFPA 4 as approved by the fire code official.

Section 901.6.3 is amended to read as follows:

901.6.3 Records. Records of all system inspections, tests and maintenance required by the referenced standard shall be maintained on the premises for a minimum of five years. See 907.7 & 907.8 for fire alarm system inspection, testing and maintenance documentation requirements.

Section 903 AUTOMATIC SPRINKLER SYSTEMS

Section 903.2 Where required.

Section 903.2.18 Group U private garages and carports accessory to Group R-3 occupancies.

Section 903.2 is amended to read as follows:

Section 903.2 Where required. Approved automatic sprinkler systems in new and existing buildings and structures shall be provided in the locations described in this Section or in Sections 903.2.1 through 903.2.12 whichever is the more restrictive and Sections 903.2.14 through 903.2.21.

For the purposes of this section, firewalls and fire barriers used to separate building areas shall be constructed in accordance with the California Building Code and shall be without openings or penetrations.

1. An automatic sprinkler system shall be provided throughout all new buildings and structures, other than Group R occupancies, except as follows:
 - a. Buildings and structures not located in any Wildland-Urban Interface and not exceeding 1,200 square feet of fire area.
 - b. Buildings and structures located in any Wildland-Urban Interface Fire Area and not exceeding 500 square feet of fire area.
 - c. Canopies, constructed in accordance with CBC 406.7.2, used exclusively for weather protection of vehicle fueling pads per CBC 406.7.1 and not exceeding 5,000 square feet of fire area.
 - d. Group S-2 or U occupancies, including photovoltaic support structures, used exclusively for vehicle parking which meet all of the following:
 - i. Noncombustible construction.
 - ii. Maximum 5,000 square feet in building area.
 - iii. Structure is open on not less than three (3) sides nor 75% of structure perimeter.
 - iv. Minimum of 10 feet separation from existing buildings, or similar structures, unless area is separated by fire walls

complying with California Building Code 706.

2. An automatic sprinkler system shall be installed throughout all new buildings with a Group R fire area.

Exception: Detached Accessory Dwelling Unit, provided that all of the following are met:

- a. The unit meets the definition of an Accessory Dwelling Unit as defined in the Government Code Section 65852.2.
 - b. The existing primary residence does not have automatic fire sprinklers.
 - c. The accessory detached dwelling unit does not exceed 1,200 square feet in size.
 - d. The unit is on the same lot as the primary residence.
 - e. The unit meets all apparatus access and water supply requirements of Chapter 5 and Appendix B of the 2022 California Fire Code.
3. An approved automatic fire sprinkler system shall be installed in new manufactured homes (as defined in California Health and Safety Code Sections 18007 and 18009) and multifamily manufactured homes with two dwelling units (as defined in California Health and Safety Code Section 18008.7) in accordance with Title 25 of the California Code of Regulations.
 4. An approved automatic sprinkler system shall be provided throughout all existing buildings, when additions are made that exceed fifty (50) percent and/or seven hundred and fifty (750) square feet of existing floor areas (area calculations shall not include existing basement floor areas).
 5. An approved automatic sprinkler system shall be provided throughout all new basements regardless of size and throughout existing basements that are expanded by more than 50%.
 6. An approved automatic sprinkler system shall be provided throughout existing buildings and structures when alterations or additions are made that create conditions described in Sections 903.2.1 through 903.2.18.
 7. Any change in the character of occupancy or in use of any building with a fire area equal to or greater than 3,600 square feet which, in the opinion of the fire code official or building official, would place the building into a more hazardous division of the same occupancy group or into a different group of occupancies and constitutes a greater degree of life safety¹ or increased fire risk², shall require the installation of an approved fire automatic fire sprinkler system.

¹ Life Safety – Shall include, but not limited to: Increased occupant load, public assembly areas, public meeting areas, churches, indoor amusement attractions, buildings with complex exiting systems due to increased occupant loads, large schools/day-care facilities, large residential care facilities housing non-ambulatory clients.

² Fire Risks – Shall include, but not limited to: High-piled combustible storage, woodworking operations, hazardous operations using hazardous materials, increased fuel loads (storage of moderate to highly combustible materials), increased sources of ignition (welding, automotive repair with the use of flammable liquids and open flames).

8. The obligation to provide compliance with these fire sprinkler regulations may not be evaded by performing a series of small additions and/or alterations undertaken over a three-year period and/or two code cycles. The permit issuance dates of past additions and/or alterations where these regulations were in effect shall be used for determining compliance.
 - a. Any submittal for building permits which exceed fifty (50) percent and/or seven hundred and fifty (750) square feet of existing floor areas (area calculations shall not include existing basement floor areas and any non-habitable floor areas i.e., garages) during the three-year period shall comply with fire sprinkler regulations.
 - b. No waiver shall be granted from compliance with fire sprinklers.

Section 903.2.11.7 is added as follows:

903.2.11.7 Chemical Fume Hood Fire Protection. Approved automatic fire extinguishing systems shall be provided in chemical fume hoods in the following cases:

3. Existing hoods having interiors with a flame spread index greater than 25 in which flammable liquids are handled.
4. If a hazard assessment determines that an automatic extinguishing system is required for the chemical fume hood, then the applicable automatic fire protection system standard shall be followed.

SECTION 907 FIRE ALARM AND DETECTION SYSTEMS

Section 907.8 is amended as follows:

907.8 Inspection, testing and maintenance. The maintenance and testing schedules and procedures for fire alarm and fire detection systems shall be in accordance with Sections 907.8.1 through 907.8.4 and NFPA 72. *Records of inspection, testing and maintenance shall be documented using NFPA 72 record of inspection and testing forms.*

Section 909 SMOKE CONTROL SYSTEMS

Section 909.20.1 Schedule

Section 909.20.1 is amended to read as follows:

909.20.1 Schedule. A routine maintenance and operational testing program shall be initiated immediately after the smoke control system has passed the acceptance tests. A written schedule for routine maintenance and operational testing shall be established and operational testing shall occur at least annually.

Chapter 12 ENERGY SYSTEMS

SECTION 1202 DEFINITIONS

Section 1202.1 is amended as follows:

1202.1 Definitions. The following terms are defined in Chapter 2:

BATTERY SYSTEM, STATIONARY STORAGE.

BATTERY TYPES.

CAPACITOR ENERGY STORAGE SYSTEM.

CRITICAL CIRCUIT.

EMERGENCY POWER SYSTEM.

ENERGY STORAGE MANAGEMENT SYSTEMS.

ENERGY STORAGE SYSTEM (ESS).

ENERGY STORAGE SYSTEM, ELECTROCHEMICAL.

ENERGY STORAGE SYSTEM, MOBILE.

ENERGY STORAGE SYSTEM, WALK-IN UNIT.

ENERGY STORAGE SYSTEM CABINET.

ENERGY STORAGE SYSTEM COMMISSIONING.

ENERGY STORAGE SYSTEM DECOMMISSIONING.

FUEL CELL POWER SYSTEM, STATIONARY.

LARGE-SCALE FIRE TESTING

PORTABLE GENERATOR.

STANDBY POWER SYSTEM.

SECTION 1207 ELECTRICAL ENERGY STORAGE SYSTEMS (ESS)

Section 1207.1.5 is amended as follows:

1207.1.5 Large-scale fire test. Where required elsewhere in Section 1207, large-scale fire testing shall be conducted in accordance with *NFPA 855, and* UL 9540A. The testing shall be conducted or witnessed and reported by an approved testing laboratory and show that a fire involving one ESS will not propagate to an adjacent ESS, and where installed within buildings, enclosed areas and walk-in units will be contained within the room, enclosed area or walk-in unit for a duration equal to the fire-resistance rating of the room separation specified in Section 1207.7.4. The test

report shall be provided to the fire code official for review and approval in accordance with Section 104.8.2.

Section 1207.2.2.1 is amended as follows:

1207.2.2.1 Ongoing inspection and testing. Systems that monitor and protect the ESS installation shall be inspected and tested in accordance with the manufacturer’s instructions and the operation and maintenance manual. Inspection and testing records shall be maintained in the operation and maintenance manual and made available to the fire code official upon request.

Section 1207.5.2 is amended as follows:

1207.5.2 Maximum allowable quantities. Fire areas within rooms, areas and walk-in units containing electrochemical ESS shall not exceed the maximum allowable quantities in Table 1207.5. The allowable number of fire areas, maximum allowable quantity, and fire-resistance rating of fire-barriers shall comply with Table 1207.5.1.

Exceptions: Where approved by the fire code official, rooms, areas and walk-in units containing electrochemical ESS that exceed the amounts in Table 1207.5 shall be permitted based on a hazardous mitigation analysis in accordance with Section 1207.1.4 and large-scale fire testing complying with Section 1207.1.5.

1. Lead-acid and nickel-cadmium battery systems installed in facilities under the exclusive control of communications utilities and operating at less than 50 VAC and 60 VDC in accordance with NFPA 76.
2. Dedicated-use buildings in compliance with Section 1207.7.1.

TABLE 1207.5.1 DESIGN AND NUMBER OF ESS FIRE AREAS				
STORY		PERCENTAGE OF MAXIMUM ALLOWABLE QUANTITY PER FIRE AREA	NUMBER OF FIRE AREAS PER STORY	FIRE-RESISTANCE RATING FOR FIRE BARRIERS IN HOURS
Above grade plan	Higher than 9	25	1	3
	7-9	50	2	2
	6	50	2	2
	5	50	2	2
	4	75	4	2
	3	100	6	2
	2	100	6	2

	1	100	6	2
Below grade plan	1	100	4	3
	2	50	2	3
	Lower than 2	Not Allowed	Not Allowed	Not Allowed

Section 1207.5.5 is amended as follows:

1207.5.5 Fire suppression systems. Rooms and areas within buildings and walk-in units containing electrochemical ESS shall be protected by an automatic fire suppression system designed and installed in accordance with one of the following:

1. An automatic sprinkler system designed and installed in accordance with Section 903.3.1.1 with a minimum density of 0.3 gpm/ft² (1.14 L/min) based on the fire area or 2,500 square-foot (232 m²) design area, whichever is larger.
2. Where approved, an automatic sprinkler system designed and installed in accordance with Section 903.3.1.1 with a sprinkler hazard classification based on large-scale fire testing complying with Section 1207.1.5.
3. The following alternative automatic fire-extinguishing systems designed and installed in accordance with Section 904, provided that the installation is approved by the fire code official based on large-scale fire testing complying with Section 1207.1.5:
 - 3.1. NFPA 12, *Standard on Carbon Dioxide Extinguishing Systems*.
 - 3.2. NFPA 15, *Standard for Water Spray Fixed Systems for Fire Protection*.
 - 3.3. NFPA 750, *Standard on Water Mist Fire Protection Systems*.
 - 3.4. NFPA 2001, *Standard on Clean Agent Fire-Extinguishing Systems*.
 - 3.5. NFPA 2010, *Standard for Fixed Aerosol Fire-Extinguishing Systems*.

Exception: Fire suppression systems for lead-acid and nickel-cadmium battery systems at facilities under the exclusive control of communications utilities that operate at less than 50 VAC and 60 VDC shall be provided where required by NFPA 76.

Section 1207.11.3 is amended as follows:

1207.11.3 Location. ESS shall be installed only in the following locations:

1. Detached garages and detached accessory structures.
2. Attached garages separated from the dwelling unit living space and sleeping units in accordance with Section R302.6.
3. Outdoors or on the exterior side of the exterior walls not less than 3 feet (914 mm) from doors and windows directly entering the dwelling unit and not below or above any emergency escape and rescue openings.
4. Enclosed utility closets, basements, storage, or utility spaces within dwelling units with finished or noncombustible walls and ceilings. Walls and ceilings of

unfinished wood-framed construction shall be provided with not less than 5/8-inch (15.9 mm) Type X gypsum wallboard.

5. ESS shall not be installed in sleeping rooms, closets, spaces opening directly into sleeping rooms or in habitable spaces of dwelling units.

Section 1207.11.6 is amended as follows:

1207.11.6 Fire detection. ESS installed in Group R-3 and R-4 occupancies shall comply with the following:

1. Rooms and areas within dwellings units, sleeping units, basements and attached garages in which ESS are installed shall be protected by smoke alarms in accordance with Section 907.2.11.
2. A listed heat alarm interconnected to the smoke alarms shall be installed in locations within dwelling units, sleeping units, and attached garages where smoke alarms cannot be installed based on their listing.

Exceptions:

1. A listed heat detector may be used in place of a heat alarm, so long as it is interconnected with devices that provide an audible alarm at all sleeping areas.
2. A fire sprinkler associated with an approved automatic sprinkler system that triggers an audible alarm upon activation of the waterflow switch, may be used in place of a heat alarm.

Chapter 33 FIRE SAFETY DURING CONSTRUCTION AND DEMOLITION

Section 3305 PRECAUTIONS AGAINST FIRE

Section 3305.5 is amended to read as follows:

3305.5 Fire watch. Where required by the fire code official or the site safety plan established in accordance with Section 3303.1, a fire watch shall be provided for building demolition and for building construction. Fire watch is not intended to facilitate occupancy during ongoing construction in a new building.

Section 3305.10 is amended to read as follows:

Section 3305.10 Fire Walls.

When firewalls are required in combustible construction, the wall construction shall be completed (with all openings protected) immediately after the building is sufficiently weather protected at the location of the wall(s).

Section 3311 ACCESS FOR FIRE FIGHTING

Add Section 3311.1.1 to read:

3311.1.1 Fire Department Access Roadways: All construction sites shall be accessible by fire department apparatus by means of roadways having an all-weather driving surface of not less than 20ft. of unobstructed width. The roads shall have the ability to withstand the live loads of fire apparatus and have a minimum 13ft. 6 in. of vertical clearance. Dead end fire access roads in excess of 150 ft. in length shall be provided with approved turnarounds.

When approved by the Fire Code Official, temporary access roadways may be utilized until such time that the permanent roadways are installed. As a minimum, the roadway shall consist of a compacted subbase and six (6) inches of road base material (Class 2 aggregate base rock) both compacted to a minimum 95% and sealed. The perimeter edges of the roadway shall be contained and delineated by curb and gutter or other approved method. The use of geotextile reinforcing fabric underlayment or soils lime-treatment may be required if so, determined by the project civil engineer. Provisions for surface drainage shall also be provided where necessary. The integrity of the roadway shall be maintained at all times.

Section 3312 MEANS OF EGRESS

Section 3312.1 Stairways Required.

Section 3312.4 Required Means of Egress.

Section 3312.1 is amended to read as follows:

Section 3312.1 Stairways Required.

Each level above the first story in new multi-story buildings that require two exit stairways shall be provided with at least two usable exit stairways after the floor decking is installed. The stairways shall be continuous and discharge to grade level. Stairways serving more than two floor levels shall be enclosed (with openings adequately protected) after exterior walls/windows are in place. Exit stairs in new and in existing, occupied buildings shall be lighted and maintained clear of debris and construction materials at all times.

Exception: For new multi-story buildings, one of the required exit stairs may be obstructed on not more than two contiguous floor levels for the purposes of stairway construction (i.e., installation of gypsum board, painting, flooring, etc.).

Section 3312.4 is added to read as follows:

Section 3312.4 Required Means of Egress.

All buildings under construction shall have at least one unobstructed means of egress. All means of egress shall be identified in written fire safety plan as required by Section 3303.1.

Section 3315 AUTOMATIC FIRE SPRINKLER SYSTEM

Section 3315.1 is amended as follows:

3315.1 Completion before occupancy. In buildings where an automatic sprinkler system is required by this code or the California Building Code, it shall be unlawful to occupy any portion of a building or structure until the automatic sprinkler system installation has been tested and approved.

In new buildings of combustible construction where, automatic fire sprinkler systems are required to be installed, the system shall be placed in service as soon as possible. Immediately upon the completion of sprinkler pipe installation on each floor level, the piping shall be hydrostatically tested and inspected. After inspection approval from the Fire department, each floor level of sprinkler piping shall be connected to the system supply riser and placed into service with all sprinkler heads uncovered. Protective caps may be installed on the active sprinklers during the installation of drywall, texturing and painting, but shall be removed immediately after this work is completed. For system activation notification, an exterior audible waterflow alarm shall bell can be installed and connected to the sprinkler waterflow device prior to installation of the monitoring system.

For buildings equipped with fire sprinkler systems that are undergoing alterations, the sprinkler system(s) shall remain in service at all times except when system modifications are necessary. Fire sprinkler systems undergoing modifications shall be returned to service at the end of each workday unless otherwise approved by the fire department. The General contractor or his/her designee shall check the sprinkler control valve(s) at the end of each workday to confirm that the system has been restored to service.

Chapter 49 REQUIREMENTS FOR WILDLAND-URBAN INTERFACE FIRE AREAS

Chapter 49 of the 2022 California Fire Code is amended as follows:

Section 4901 GENERAL

Section 4901.3 is added as follows:

4901.3 Where applicable. These requirements shall apply to all areas within the City of Los Altos as set forth and delineated on the map entitled "Wildland-Urban Interface Fire Area" which map and all notations, references, data and other information shown thereon are hereby adopted and made a part of this Chapter. The map properly attested, shall be on file in the Office of the City of Los Altos.

Section 4901.3 is added as follows:

4901.4 Exemptions. These requirements shall not apply to any land or water area acquired or managed for one or more of the following purposes or uses:

1. Habitat for endangered or threatened species, or any species that is a candidate for listing as an endangered or threatened species by the state or federal government.
2. Lands kept in a predominantly natural state as habitat for wildlife, plant, or animal communities.
3. Open space lands that are environmentally sensitive parklands.
4. Other lands having scenic values, as declared by the local agency, or by state or federal law.

Section 4906 VEGETATION MANAGEMENT

Section 4906.1.1 is added as follows:

4906.1.1 Hazardous vegetation and fuels shall be managed to reduce the severity of potential exterior wildfire exposure to buildings, to reduce the risk of fire spreading to buildings, and provide for safe access for emergency wildland fire equipment and civilian evacuation concurrently, as required by applicable laws and standards.

Section 4906.1.2 is added as follows:

4906.1.2 Maintenance required. Maintenance is required to ensure conformance with these standards and measures, and to assure continued availability, access, and utilization, of the defensible space during a wildfire.

Section 4906.1.3 is added as follows:

4906.1.3 Additional measures. No person subject to these regulations shall permit any fire hazard, as defined in this chapter, to exist on premises under their control, or fail to take immediate action to abate a fire hazard when requested to do so by the enforcing agency.

Section 4906.1.4 is added as follows:

4906.1.4 Exemption. For the purposes of this chapter, vegetation removal or management, undertaken in whole or in part, for fire prevention or suppression purposes shall not be deemed to alter the natural condition of public property.

Section 4907 DEFENSIBLE SPACE

Section 4907.3 is amended as follows:

4907.3 Requirements. Hazardous vegetation and fuels around all buildings, roads, driveways, and structures shall be maintained in accordance with the following laws and regulations:

1. Public Resources Code, Sections 4291 through 4296.
2. California Code of Regulations, Title 14, Division 1.5, Chapter 7, Subchapter 3, Article 3, Section 1299.03.
3. California Government Code, Sections 51175 - 51189.
4. California Code of Regulations, Title 19, Division 1, Chapter 7, Subchapter 1, Section 3.07.
5. Any local ordinance of the City of Los Altos.

Chapter 50. HAZARDOUS MATERIALS-GENERAL PROVISIONS

Chapter 50 of the 2022 California Fire Code and 2021 International Fire Code are amended as follows:

Section 5001 GENERAL

Section 5001.2.2.2 is amended as follows:

5001.2.2.2 Health Hazards The material categories listed in this section are classified as health hazards. A material with a primary classification as a health hazard can also pose a physical hazard.

1. Highly toxic and toxic materials.
2. Corrosive materials.
3. Moderately toxic gas.
4. Health hazards - Other.

Section 5002 DEFINITIONS

Amend Section 5002.1 to read:

5002.1 Definitions. The following terms are defined in Chapter 2:

BOILING POINT.
CEILING LIMIT.
CHEMICAL.
CHEMICAL NAME.
CLOSED CONTAINER.
CONTAINER.
CONTROL AREA.
CYLINDER.
DAY BOX.
DEFLAGRATION.
DESIGN PRESSURE.
DETACHED BUILDING.
DISPENSING.
EXCESS FLOW CONTROL.
EXHAUSTED ENCLOSURE.
EXPLOSION.
FLAMMABLE VAPORS OR FUMES.
GAS CABINET.
GAS ROOM.
HANDLING.
HAZARDOUS MATERIALS.
HEALTH HAZARD.
HEALTH HAZARD – OTHER.
IMMEDIATELY DANGEROUS TO LIFE AND
HEALTH (IDLH).
INCOMPATIBLE MATERIALS.
LIQUID.
LOWER EXPLOSIVE LIMIT (LEL).
LOWER FLAMMABLE LIMIT (LFL).
MAXIMUM ALLOWABLE QUANTITY PER CONTROL AREA.
MODERATELY TOXIC GAS.
NORMAL TEMPERATURE AND PRESSURE (NTP).
OUTDOOR CONTROL AREA.
PERMISSIBLE EXPOSURE LIMIT (PEL).
PESTICIDE.
PHYSICAL HAZARD.
PRESSURE VESSEL.
SAFETY CAN.
SAFETY DATA SHEET (SDS).
SECONDARY CONTAINMENT.
SEGREGATED.
SOLID.

SPILL CONTROL.
STORAGE, HAZARDOUS MATERIALS.
SYSTEM.
TANK, ATMOSPHERIC.
TANK, PORTABLE.
TANK, STATIONARY.
TANK VEHICLE.
UNAUTHORIZED DISCHARGE.
USE (MATERIAL).
VAPOR PRESSURE.

Section 5003 GENERAL REQUIREMENTS

Section 5003.1.3.1 is added as follows:

5003.1.3.1 Toxic, Highly Toxic, Moderately Toxic Gases and Similarly Used or Handled Materials. The storage, use and handling of toxic, highly toxic, and moderately toxic gases in amounts exceeding Table 6004.2.1.4 shall be in accordance with this chapter and Chapter 60. Any toxic, highly toxic, or moderately toxic material that is used or handled as a gas or vapor shall be in accordance with the requirements for toxic, highly toxic, or moderately toxic gases.

Section 5003.1.5 is added as follows:

5003.1.5 Health Hazards - Other. The storage, use and handling of materials classified as other health hazards including carcinogens, irritants and sensitizers in amounts exceeding 810 cubic feet for gases, 55 gallons for liquids and 5,000 pounds for solids shall be in accordance with Section 5003.

Section 5003.1.6 is added as follows:

5003.1.6 Additional Spill Control and Secondary Containment Requirements. In addition to the requirements set forth in Section 5004.2. An approved containment system is required for any quantity of hazardous materials that are liquids or solids at normal temperature, and pressure (NTP) where a spill is determined to be a plausible event and where such an event would endanger people, property, or the environment. The approved containment system may be required to include a combination of spill control and secondary containment meeting the design and construction requirements set forth in Section 5004.2.

Section 5003.2.2.1 is amended as follows:

5003.2.2.1 Design and Construction. Piping, tubing, valves, fittings, and related

components used for hazardous materials shall be in accordance with the following:

1. Piping, tubing, valves, fittings, and related components shall be designed and fabricated from materials that are compatible with the material to be contained and shall be of adequate strength and durability to withstand the pressure, structural and seismic stress, and exposure to which they are subject.
2. Piping and tubing shall be identified in accordance with ASME A13.1 and the *Santa Clara County Fire Chiefs Marking Requirements and Guidelines for Hazardous Materials and Hazardous Waste* to indicate the material conveyed.
3. Manual valves or automatic remotely activated fail-safe emergency shutoff valves shall be installed on supply piping and tubing and provided with ready access at the following locations:
 - 3.1. The point of use.
 - 3.2. The tank, cylinder, or bulk source.
4. Manual emergency shutoff valves and controls for remotely activated emergency shutoff valves shall be clearly visible, provided with ready access and identified in an approved manner.
5. Backflow prevention or check valves shall be provided where the backflow of hazardous materials could create a hazardous condition or cause the unauthorized discharge of hazardous materials.
6. Where gases or liquids having a hazard ranking of:
 - Health hazard Class 3 or 4
 - Flammability Class 4
 - Reactivity Class 4

in accordance with NFPA 704 are carried in pressurized piping above 15 pounds per square inch gauge (psig)(103 Kpa), an approved means of leak detection, emergency shutoff or excess flow control shall be provided. Where the piping originates from within a hazardous material storage room or area, the excess flow control shall be located within the storage room or area. Where the piping originates from a bulk source, the excess flow control shall be located as close to the bulk source as practical.

Exceptions:

1. Piping for inlet connections designed to prevent backflow.
 2. Piping for pressure relief devices.
7. Secondary containment or equivalent protection from spills or leaks shall be provided for piping for liquid hazardous materials and for highly toxic and toxic corrosive gases above threshold quantities listed in Table 6004.2.1.4. Secondary containment includes but is not limited to double-walled piping.

Exceptions:

1. Secondary containment is not required for toxic corrosive gases if the piping is constructed of inert materials.
2. Piping under sub-atmospheric conditions if the piping is equipped with an alarm and fail-safe-to-close valve activated by a loss of vacuum.

8. Expansion chambers shall be provided between valves whenever the regulated gas may be subjected to thermal expansion. Chambers shall be sized to provide protection for piping and instrumentation and to accommodate the expansion of regulated materials.

Section 5003.2.2.2 is amended as follows:

5003.2.2.2 Additional Regulation for Supply Piping for Health Hazard Materials. Supply piping and tubing for gases and liquids having a health hazard ranking of 3 or 4 in accordance with NFPA 704 shall be in accordance with ASME B31.3 and the following:

- 8.1. Piping and tubing utilized for the transmission of highly toxic, toxic, or highly volatile corrosive liquids and gases shall have welded, or brazed connections threaded or flanged connections throughout except for connections within an exhausted ventilated enclosure if the material is a gas, or an approved method of drainage or containment is provided for connections if the material is a liquid.
- 8.2. Piping and tubing shall not be located within corridors, within any portion of a means of egress required to be enclosed in fire-resistance-rated construction or in concealed spaces in areas not classified as Group H Occupancies.
- 8.3. All primary piping for toxic, highly toxic, and moderately toxic gases shall pass a helium leak test of 1×10^{-9} cubic centimeters/second where practical, or shall pass testing in accordance with an approved, nationally recognized standard. Tests shall be conducted by a qualified "third party" not involved with the construction of the piping and control systems.

Exception: Piping and tubing within the space defined by the walls of corridors and the floor or roof above or in concealed spaces above other occupancies where installed in accordance with Section 415.11.7.4 of the *California Building Code* for Group H-5 occupancies.

Section 5003.5.2 is added as follows:

5003.5.2 Ventilation Ducting. Ducts venting hazardous materials operations shall be labeled with the hazard class of the material being vented and the direction of flow.

Section 5003.5.3 is added as follows:

5003.5.3 "H" Occupancies. In "H" occupancies, all piping and tubing may be required to be identified when there is any possibility of confusion with hazardous materials transport tubing or piping. Flow direction indicators are required.

Section 5003.10.4 is amended as follows:

5003.10.4 Elevators utilized to transport hazardous materials.

5003.10.4.1 When transporting hazardous materials, elevators shall have no other passengers other than the individual(s) handling the chemical transport cart.

5003.10.4.1.1 When transporting cryogenic or liquefied compressed gases, there shall be no occupants in the elevator.

5003.10.4.2 Hazardous materials liquid containers shall have a maximum capacity of 20 liters (5.28 gal).

5003.10.4.3 Toxic, moderately toxic, and highly toxic gases shall be limited to a container of a maximum water capacity of 1 pound.

5003.10.4.4 When transporting cryogenic or liquefied compressed gases, means shall be provided to prevent the elevator from being summoned to other floors.

Section 5004 STORAGE

Section 5004.2.1 is amended as follows:

5004.2.1 Spill Control for Hazardous Material Liquids. Rooms, buildings, or areas used for storage of hazardous material liquids—shall be provided with spill control to prevent the flow of liquids to adjoining areas. Floors in indoor locations and similar surfaces in outdoor locations shall be constructed to contain a spill from the largest single vessel by one of the following methods:

1. Liquid-tight sloped or recessed floors in indoor locations or similar areas in outdoor locations.
2. Liquid-tight floors in indoor and outdoor locations or similar areas provided with liquid-tight raised or recessed sills or dikes.
3. Sumps and collection systems
4. Other approved engineered systems.

Except for surfacing, the floors, sills, dikes, sumps, and collection systems shall be constructed of noncombustible material, and the liquid-tight seal shall be compatible with the material stored. When liquid-tight sills or dikes are provided, they are not required at perimeter openings having an open-grate trench across the opening that connects to an approved collection system.

Section 5004.2.2.2 is amended as follows:

5004.2.2.2 Incompatible Materials. Incompatible materials used in open systems shall be separated from each other in *independent secondary containment systems*.

Chapter 54 CORROSIVE MATERIALS

Chapter 54 of the 2022 California Fire Code is adopted with the following amendments:

Section 5402 DEFINITION

Section 5402.1 is amended as follows:

5402.1 Definition. The following term is defined in Chapter 2:

CORROSIVE.

CORROSIVE LIQUIDS.

Chapter 56 EXPLOSIVES AND FIRWORKS

Section 5601 GENERAL

Section 5601.1.3 Fireworks.

Section 5601.1.1.3 is added to read as follows:

Section 5601.1.1.3 Fireworks. The possession, manufacture, storage, sale, handling, and use of fireworks, including those fireworks classified as Safe and Sane by the California State Fire Marshal, are prohibited.

Exceptions: The use of fireworks for firework displays as allowed in Section 5608.

Chapter 57 FLAMMABLE AND COMBUSTIBLE LIQUIDS

Section 5704 STORAGE

Section 5704.2.7.5.8 Overfill Prevention.

Section 5704.2.7.5.9 Automatic Filling of Tanks.

Section 5704.2.9.6.1 Locations where above-ground tanks are prohibited

Section 5706.2.4.4 Locations where above-ground tanks are prohibited.

Section 5707.3.3 Site Plan

Section 5704.2.7.5.8 is amended to read as follows and the exception in the Section

is deleted:

Section 5704.2.7.5.8 Overfill Prevention.

An approved means or method in accordance with Section 5704.2.9.7.5. shall be provided to prevent the overfill of all Class I, II and IIIA liquid storage tanks. Storage tanks in refineries, bulk plants or terminals regulated by Sections 5706.4 or 5706.7 shall have overfill protection in accordance with API 2350.

Exception: Outside aboveground tanks with a capacity of 1320 gallons (5000 L) or less need only comply with Section 5704.2.9.7.5 (Item 1, Sub-item 1.1).

An approved means or method in accordance with Section 5704.2.9.7.5 shall be provided to prevent the overfilling of Class IIIB liquid storage tanks connected to fuel-burning equipment inside buildings.

Section 5704.2.7.5.9 is added to read as follows:

Section 5704.2.7.5.9 Automatic Filling of Tanks. Systems that automatically fill flammable or combustible liquid tanks shall be equipped with overfill protection, approved by the fire code official, that sends an alarm signal to a constantly attended location and immediately stops the filling of the tank. The alarm signal and automatic shutoff shall be tested on an annual basis and records of such testing shall be maintained on-site for a period of five (5) years.

Section 5704.2.9.6.1 is amended to read as follows:

5704.2.9.6.1 Locations where above-ground tanks are prohibited. Storage of flammable or combustible liquids in outside aboveground tanks is prohibited, are hereby established as all locations of the City of Los Altos that are residential or congested commercial areas as determined by the fire code official.

Section 5706.2.4.4 is amended to read as follows:

5706.2.4.4 Locations where above-ground tanks are prohibited. Storage of Class I and II liquids in above-ground tanks outside of buildings is prohibited

In all locations of the City of Los Altos which are residential or congested commercial areas as determined by the fire code official.

Section 5707.3.3 is amended to read as follows:

5707.3.3 Site plan. A site plan shall be developed for each location at which mobile fueling occurs. The site plan shall be in sufficient detail to indicate the following:

1. All buildings and structures.
2. Lot lines or property lines.
3. Electric car chargers.
4. Solar photovoltaic parking lot canopies.
5. Appurtenances on-site and their use or function.
6. All uses adjacent to the lot lines of the site.
7. Fueling locations.
8. Locations of all storm drain openings and adjacent waterways or wetlands.
9. Information regarding slope, natural drainage, curbing and impounding.
10. How a spill will be kept on the site property.
11. Scale of the site plan.

Chapter 58 FLAMMABLE GASES AND FLAMMABLE CRYOGENIC FLUIDS.

Section 5806.2 Limitations

Section 5809.3.4 Site Plan

Section 5809.3.4 is amended to read as follows:

5809.3.4 Site plan. For other than emergency roadside service, a site plan shall be developed for each location at which mobile gaseous hydrogen fueling occurs. The site plan shall be in sufficient detail to indicate, all buildings, structures, lot lines, property lines and appurtenances on site and their use and function, and the scale of the site plan.

Chapter 60 HIGHLY TOXIC AND TOXIC MATERIALS

Chapter 60 of the 2022 California Fire Code and 2021 International Code is amended as follows:

Section 6001 GENERAL

Section 6001.1 is amended as follows:

6001.1 Scope. The storage and use of highly toxic, toxic, and moderately toxic materials shall comply with this chapter. Compressed gases shall also comply with Chapter 53.

Exceptions:

1. Display and storage in Group M and storage in Group S occupancies complying with Section 5003.11.
2. Conditions involving pesticides or agricultural products as follows:
 - 2.1 Application and release of pesticide, agricultural products and materials intended for use in weed abatement, erosion control, soil amendment or similar applications when applied in accordance with the manufacturer's instruction and label directions.
 - 2.2 Transportation of pesticides in compliance with the Federal Hazardous Materials Transportation Act and regulations thereunder.
 - 2.3 Storage in dwellings or private garages of pesticides registered by the US Environmental Protection Agency to be utilized in and around the home, garden, pool, spa, and patio.

Section 6004 HIGHLY TOXIC AND TOXIC COMPRESSED GASES

Section 6004.1 is amended as follows:

6004.1 General. The storage and use of highly toxic, toxic, and moderately toxic compressed gases shall comply with this section.

6004.1.1 Special limitations for indoor storage and use by occupancy. The indoor storage and use of highly toxic, toxic, and moderately toxic compressed gases in certain occupancies shall be subject to the limitations contained in Sections 6004.1.1.1 through 6004.1.1.3.

6004.1.1.1 Group A, E, I or U occupancies. Moderately toxic, toxic, and highly toxic compressed gases shall not be stored or used within Group A, E, I or U occupancies.

Exception: Cylinders not exceeding 20 cubic feet (0.566 m³) at normal temperature and pressure (NTP) are allowed within gas cabinets or fume hoods.

6004.1.1.2 Group R occupancies. Moderately toxic, toxic, and highly toxic compressed gases shall not be stored or used in Group R occupancies.

6004.1.1.3 Offices, retail sales and classrooms. Moderately toxic, toxic, and highly toxic compressed gases shall not be stored or used in offices, retail sales or classroom portions of Group B, F, M or S occupancies.

Exception: In classrooms of Group B occupancies, cylinders with a capacity not exceeding 20 cubic feet (0.566 m³) at NTP are allowed in gas cabinets or fume hoods.

Section 6004.2 is amended as follows:

6004.2 Indoor storage and use. The indoor storage and use of highly toxic, toxic, and moderately toxic compressed gases shall be in accordance with Sections 6004.2.1 through 6004.2.2.10.3.

Section 6004.2.1 is amended as follows:

6004.2.1 Applicability. The applicability of regulations governing the indoor storage and use of highly toxic, toxic, and moderately toxic compressed gases shall be as set forth in Sections 6004.2.1.1 through 6004.2.1.4.

Section 6004.2.1.4 is amended as follows:

6004.2.1.4 Quantities exceeding the minimum threshold quantities but not exceeding the maximum allowable quantities per control area. The indoor storage or use of highly toxic, toxic, and moderately toxic gases in amounts exceeding the minimum threshold quantities per control area set forth in Table 6004.2.1.4 but not exceeding maximum allowable quantity per control area set forth in Table 5003.1.1(2) shall be in accordance with Sections 5001, 5003, 6001, 6004.1, and 6004.4

Add Table 6004.2.1.4 as follows:

Minimum Threshold Quantities for Highly Toxic, Toxic and Moderately Toxic Gases for Indoor Storage and Use	
Highly Toxic	20
Toxic	405 cubic feet
Moderately Toxic	405 cubic feet

Section 6004.4 is amended as follows:

6004.4. General indoor requirements. The general requirements applicable to the indoor storage and use of highly toxic, toxic, and moderately toxic compressed gases shall be in accordance with Sections 6004.4 through 6004.4.8.2

6004.4.1 Cylinder and tank location. Cylinders shall be located within gas cabinets, exhausted enclosures, or gas rooms. Portable and stationary tanks shall be located within gas rooms or exhausted enclosures.

Exceptions:

1. Where a gas detection system is provided in accordance with 6004.4.8

6004.4.2. Ventilated areas. The room or area in which gas cabinets or exhausted enclosures are located shall be provided with exhaust ventilation. Gas cabinets or exhausted enclosures shall not be used as the sole means of exhaust for any room or area.

6004.4.3. Piping and controls. In addition to the requirements of Section 5003.2.2, piping and controls on stationary tanks, portable tanks, and cylinders shall comply with the following requirements:

1. Stationary tanks, portable tanks, and cylinders in use shall be provided with a means of excess flow control on all tank and cylinder inlet or outlet connections.

Exceptions:

1. Inlet connections designed to prevent backflow.
2. Pressure relief devices.

6004.4.4 Gas rooms. Gas rooms shall comply with Section 5003.8.4 and both of the following requirements:

1. The exhaust ventilation from gas rooms shall be directed to an exhaust system.
2. Gas rooms shall be equipped with an approved automatic sprinkler system. Alternative fire- extinguishing systems shall not be used.

6004.4.5 Treatment systems. The exhaust ventilation from gas cabinets, exhausted enclosures, and gas rooms, required in Section 6004.4.1 shall be directed to a treatment system. The treatment system shall be utilized to handle the accidental release of gas and to process exhaust ventilation. The treatment system shall be designed in accordance with Sections 6004.2.2.7.1 through 6004.2.2.7.5 and Chapter 5 of the California Mechanical Code.

Exceptions:

1. Highly toxic, toxic, and moderately toxic gases—storage. A treatment system is not required for cylinders, containers, and tanks in storage where all the following controls are provided:
 - 1.1 Valve outlets are equipped with gas- tight outlet plugs or caps.
 - 1.2 Hand wheel-operated valves have handles secured to prevent movement.
 - 1.3 Approved containment vessels or containment systems are provided in accordance with Section 6004.2.2.3.
2. Highly toxic, toxic, and moderately toxic gases —use. Treatment systems are not required for highly toxic, toxic, and moderately toxic gases supplied by stationary tanks, portable tanks, or cylinders where a gas detection system complying with Section 6004.4.8 and listed or approved

automatic-closing fail- safe valves are provided. The gas detection system shall have a sensing interval not exceeding 5 minutes. Automatic-closing fail- safe valves shall be located immediately adjacent to cylinder valves and shall close when gas is detected at the permissible exposure limit (PEL) by a gas sensor monitoring the exhaust system at the point of discharge from the gas cabinet, exhausted enclosure, ventilated enclosure, or gas room.

6004.4.5.1. Design. Treatment systems shall be capable of diluting, adsorbing, absorbing, containing, neutralizing, burning or otherwise processing the contents of the largest single vessel of compressed gas. Where a total containment system is used, the system shall be designed to handle the maximum anticipated pressure of release to the system when it reaches equilibrium.

6004.4.5.2. Performance. Treatment systems shall be designed to reduce the maximum allowable discharge concentrations of the gas to one-half immediate by dangerous to life and health (IDLH) at the point of discharge to the atmosphere. Where more than one gas is emitted to the treatment system, the treatment system shall be designed to handle the worst-case release based on the release rate, the quantity and the IDLH for all compressed gases stored or used.

6004.4.5.3. Sizing. Treatment systems shall be sized to process the maximum worst-case release of gas based on the maximum flow rate of release from the largest vessel utilized. The entire contents of the largest compressed gas vessel shall be considered.

6004.4.5.4 Stationary tanks. Stationary tanks shall be labeled with the maximum rate of release for the compressed gas contained based on valves or fittings that are inserted directly into the tank. Where multiple valves or fittings are provided, the maximum flow rate of release for valves or fittings with the highest flow rate shall be indicated. Where liquefied compressed gases are in contact with valves or fittings, the liquid flow rate shall be utilized for computation purposes. Flow rates indicated on the label shall be converted to cubic feet per minute (cfm/min) (m³/s) of gas at normal temperature and pressure (NTP).

6004.4.5.5 Portable tanks and cylinders. The maximum flow rate of release for portable tanks and cylinders shall be calculated based on the total release from the cylinder or tank within the time specified in Table 6004.2.2.7.5. Where portable tanks or cylinders are equipped with approved excess flow or reduced flow valves, the worst-case release shall be determined by the maximum achievable flow from the valve as determined by the valve manufacturer or compressed gas supplier. Reduced flow and excess flow valves shall be permanently marked by the valve manufacturer

to indicate the maximum design flow rate. Such markings shall indicate the flow rate for air under normal temperature and pressure.

6004.4.6. Emergency power. Emergency power shall be provided for the following systems in accordance with Section 604:

1. Exhaust ventilation system.
2. Treatment system.
3. Gas detection system.
4. Smoke detection system.

6004.4.6.1. Fail-safe systems. Emergency power shall not be required for mechanical exhaust ventilation and treatment systems where approved fail-safe systems are installed and designed to stop gas flow.

6004.4.7. Automatic fire detection system. An approved automatic fire detection system shall be installed in rooms or areas where highly toxic, toxic, and moderately toxic compressed gases are stored or used. Activation of the detection system shall sound a local alarm. The fire detection system shall comply with Section 907.

6004.4.8. Gas detection system. A gas detection system complying with Section 916 shall be provided to detect the presence of gas at or below the PEL or ceiling limit of the gas for which detection is provided.

Exceptions:

1. A gas detection system is not required for toxic and moderately toxic gases when the physiological warning threshold level for the gas is at a level below the accepted PEL for the gas.
2. A gas detection system is not required for highly toxic, toxic, and moderately toxic gases where cylinders, portable tanks, and all non-continuously welded connects are within a gas cabinet or exhausted enclosures.

6004.4.8.1. Alarms. The gas detection system shall initiate a local alarm and transmit a signal to an approved location.

6004.4.8.2. Shut off of gas supply. The gas detection system shall automatically close the shut off valve at the source on gas supply piping and tubing related to the system being monitored for whichever gas is detected.

Exception: Automatic shutdown is not required for highly toxic, toxic, and moderately toxic compressed gas systems where all the following controls are provided:

1. Constantly attended/supervised.
2. Provided with emergency shutoff valves that have ready access.

Chapter 61 LIQUEFIED PETROLEUM GASES

Section 6104.2 is amended to read as follows:

6104.2 Maximum capacity within established limits. Within The limits referred to in Section 6104.2 of the California Fire Code, in which storage of liquefied petroleum gas is restricted, are hereby established as all locations of the City of Los Altos that are residential or congested commercial areas as determined by the fire code official.

Exception: LPG may be used for industrial operations or when natural gas would not provide a viable substitute for LPG. Portable containers for temporary heating and/or cooking uses may be permitted if stored and handled in accordance with this code. Facilities in commercial areas for refueling portable or mobile LPG containers may be approved by the fire code official on a case-by-case basis.

Chapter 64 PYROPHORIC MATERIALS

Chapter 64 of the 2022 California Fire Code and 2021 International Code is amended as follows:

Section 6405 USE

Section 6405.3.1 is amended to read:

6405.3.1 Silane distribution systems automatic shutdown. Silane distribution systems shall automatically shut down at the source upon activation of the gas detection system at levels above the alarm level and/or failure of the ventilation system for the silane distribution system.

Chapter 80 REFERENCE STANDARD

NFPA

Add the following reference standard to read:

855 – 20: Standard for the Installation of Stationary Energy Storage Systems

Appendix B FIRE-FLOW REQUIREMENTS FOR BUILDINGS

Appendix B of the 2022 California Fire Code and 2021 International Code is amended as follows:

Section B105 FIRE=FLOW REQUIRES FOR BUILDINGS

Section B105.2 is amended as follows:

B105.2 Buildings other than one- and two-family dwellings, Group R-3 and R-4 buildings and townhouses. The minimum fire-flow and flow duration for buildings other than one- and two-family dwellings, Group R-3 and R-4 buildings and townhouses shall be as specified in Tables B105.1(2) and B105.2.

Exceptions: [SFM] Group B, S-2 and U occupancies having a floor area not exceeding 1,000 square feet, primarily constructed of noncombustible exterior walls with wood or steel roof framing, having a Class A roof assembly, with uses limited to the following or similar uses:

1. California State Parks buildings of an accessory nature (restrooms).
2. Safety roadside rest areas (SRRAs), public restrooms.
3. Truck inspection facilities (TIF), CHP office space and vehicle inspection bays.
4. Sand/salt storage buildings, storage of sand and salt.

The maximum fire flow reduction for all commercial buildings greater than 30,000 square feet and residential podium buildings shall not exceed 25 percent of the fire flow specified in Table B105.1(2). The maximum fire flow reduction for all other buildings shall not exceed 50 percent of the fire flow specified in Table B105.1(2).

Appendix C FIRE HYDRANT LOCATIONS AND DISTRIBUTION

Appendix C of the 2022 California Fire Code and 2021 International Code is amended as follows:

Section C102 NUMBER OF FIRE HYDRANTS

Section C102.1 is amended to read:

C102.1 Minimum number of fire hydrants for a building. The number of fire hydrants available to a building shall be not less than the minimum specified in Table C102.1, utilizing the base fire flow without fire sprinkler reduction.

Appendix D FIRE APPARATUS ACCESS ROADS

Appendix D of the 2022 California Fire Code and 2021 International Code is amended as follows:

Section D103 MINIMUM SPECIFICATION

Section D103.1 is deleted:

D103.1 Access Road width with a hydrant. Where a fire hydrant is located on a fire apparatus access road, the minimum road width shall be 26 feet (7925 mm), exclusive of shoulders (see Figure D103.1).

Section D103.2 is amended as follows:

D103.2 Grade. The maximum grade of a fire department apparatus access road shall not exceed 15-percent, unless approved by the fire code official.

Section D103.3 is amended as follows:

D103.3 Turning radius. The required turning radius of a fire apparatus access roads shall be a minimum of 30 feet inside, and a minimum of 50 feet outside.

Section D103.4 is amended as follows:

D103.4 Dead ends. Dead-end fire apparatus access roads and/or driveways in excess of 150 feet (45 720 mm) shall be provided with width and turnaround provisions in accordance with Table D103.4 the Santa Clara County Fire Department apparatus access and turnaround standards, as approved by the fire code official.

Section D103.6 is amended as follows:

D103.6 Signs. Where required by the Fire Code Official, fire apparatus access roads shall be designated and marked as a fire lane as set forth in Section 22500.1 of the California Vehicle Code and the Santa Clara County Fire Department A-6 Standard. Signs shall have a minimum dimension of 12 inches (305 mm) wide by 18 inches (457 mm) high and have red letters on a white reflective background. Signs shall be posted on one or both sides of the fire apparatus road as required by Section D103.6.1 or D103.6.2.

SECTION 22. AMENDMENT OF CODE: Title 12, Chapter 12.26 of the Municipal Code is hereby repealed.

SECTION 23. AMENDMENT OF CODE: Title 12, Chapter 12.26 of the Municipal Code is hereby added to read as follows:

Chapter 12.26 CALIFORNIA GREEN BUILDING STANDARDS CODE

City of Los Altos local amendments to the 2022 California Green Building Standards

Code. Upon adoption of this Code in the event that there is any conflict between local amendments and the 2022 California Green Building Standards Code the most restrictive shall prevail.

**Section 12.26.010 Adoption of the California Green Building Standards Code
Section 12.26.020 Amendments, Additions or Deletions**

Section 12.26.010 Adoption of the California Green Building Standards Code

There is hereby adopted by reference as if fully set forth herein, the 2022 California Green Building Standards Code, contained in the California Code of Regulations, Title 24, Part 11, published by the International Code Council, and each and all of its regulations and provisions. One copy is on file for use and examination by the public in the office of the Building Official.

Section 12.26.020 Amendments, Additions or Deletions

The 2022 California Green Building Standards Code referred to in Section 12.26.010 is adopted, together with Chapters 1 Administration, 4 Residential Mandatory Measures, and 5 Nonresidential Mandatory Measures, of the 2022 California Green Building Standards Code, with the following amendments as follows:

Chapter 1 Section 102.4 Scope and Mandatory Compliance is hereby added to read as follows.

Section 102.4 Scope and Mandatory Compliance

A. This code contains both mandatory and voluntary green building measures. Mandatory and voluntary measures are identified in the appropriate chapters contained in this code. Compliance measures and methods shall be by one of the following measures approved by the Building Official.

The means by which compliance measures are achieved shall be mandatory measures with appendix sections voluntarily applied, building division mandatory check list, whole house Build it Green GreenPoint check list, LEED, other recognized point systems, Title 24 Part 6 Energy Efficiency Standards, or equivalent approved methods. Green Building Compliance measures in addition to checklists shall be incorporated into the project drawings approved by the Building Official prior to building permit submittal.

Prior to issuance of a building permit, the owner or responsible Registered Design Professional acting as the owner's agent shall employ and/or retain a

Qualified Green Building Professional to the satisfaction of the Building Official, and prior to final inspection shall submit verification that the project is in compliance with this ordinance.

Chapter 4 Section 4.106.4.1 Electric vehicle (EV) charging for new construction thru 4.106.4.2.2 are deleted and replaced to read as follows, based upon express findings set forth in this Ordinance.

Section 4.106.4.1 and 4.106.4.2.1 and 4.106.4.2.2 are amended to read as follows:

4.106.4.1 New one- and two-family dwellings and townhouses with attached private garages.

For each dwelling unit, install at least one Level 2 EV Ready Space in the garage. If multiple (two or more) garage parking spaces are provided for a dwelling unit, install at least two Level 2 EV Ready Spaces.

4.106.4.2.1 Multifamily development projects with less than 20 dwelling units; and hotels and motels with less than 20 sleeping units or guest rooms. The number of dwelling units, sleeping units or guest rooms shall be based on all buildings on a project site subject to this section.

1. **EV Capable.** Twenty-five (25) percent of the total number of parking spaces on a building site, provided for all types of parking facilities, shall be electric vehicle charging spaces (EV spaces) capable of supporting future Level 2 EVSE. Electrical load calculations shall demonstrate that the electrical panel service capacity and electrical system, including any on-site distribution transformer(s), have sufficient capacity to simultaneously charge all EVs at all required EV spaces at a minimum of 40 amperes.

The service panel or subpanel circuit directory shall identify the overcurrent protective device space(s) reserved for future EV charging purposes as "EV CAPABLE" in accordance with the California Energy Code.

Exceptions:

1. When EV chargers (Level 2 EVSE) are installed in a number equal to or greater than the required number of EV capable spaces.
2. When EV chargers (Level 2 EVSE) are installed in a number less than the required number of EV capable spaces, the number of EV capable spaces required may be reduced by a number equal to the number of EV chargers installed.

The following requirements apply to all multifamily development projects with less than 20 dwelling units; and hotels and motels with less than 20 sleeping units or guest rooms:

1. Calculations for the required minimum number of Level 2 EVSE spaces shall be rounded up to the nearest whole number.
2. In addition, each remaining dwelling unit with parking space(s) shall be provided with at least one Level 2 EV Ready Space.

4.106.4.2.2 Multifamily development projects with 20 or more dwelling units; and hotels and motels with 20 or more sleeping units or guest rooms. The number of dwelling units, sleeping units or guest rooms shall be based on all buildings on a project site subject to this section.

2. **EV Capable.** Twenty-five (25) percent of the total number of parking spaces on a building site, provided for all types of parking facilities, shall be electric vehicle charging spaces (EV spaces) capable of supporting future Level 2 EVSE. Electrical load calculations shall demonstrate that the electrical panel service capacity and electrical system, including any on-site distribution transformer(s), have sufficient capacity to simultaneously charge all EVs at all required EV spaces at a minimum of 40 amperes.

The service panel or subpanel circuit directory shall identify the overcurrent protective device space(s) reserved for future EV charging purposes as "EV CAPABLE" in accordance with the California Energy Code.

Exceptions:

3. When EV chargers (Level 2 EVSE) are installed in a number equal to or greater than the required number of EV capable spaces.
4. When EV chargers (Level 2 EVSE) are installed in a number less than the required number of EV capable spaces, the number of EV capable spaces required may be reduced by a number equal to the number of EV chargers installed.

The following requirements apply to all multifamily development projects with 20 or more dwelling units; and hotels and motels with 20 or more sleeping units or guest rooms:

3. Calculations for the required minimum number of Level 2 EVSE spaces shall be rounded up to the nearest whole number.
4. In addition, each remaining dwelling unit with parking space(s) shall be provided with at least one Level 2 EV Ready Space.

Chapter 5 Section 5.106.5.3 Electric vehicle (EV) charging thru 5.106.5.3.5 are deleted and replaced to read as follows, based upon express findings set forth in

this Ordinance

Section 5.106.5.3 thru 5.106.5.3.5 are amended to read as follows:

5.106.5.3 Electric vehicle (EV) charging. [N] New construction to provide electric vehicle infrastructure and facilitate electric vehicle charging shall comply with Section 5.106.5.3.1 and shall be provided in accordance with regulations in the California building Code and the California Electrical Code.

Exceptions:

1. Where there is no local utility power supply.
2. Parking spaces accessible only by automated mechanical car parking systems are not required to comply with this code section.

5.106.5.3.1 Office and Institutional buildings. In nonresidential new construction buildings designated primarily for office use and institutional buildings, with parking:

1. When 10 or more parking spaces are constructed, 50% of the available parking spaces on site shall be equipped with Level 2 EVSE;
2. An additional 20% shall be provided with at least Level 1 EV Ready Spaces; and
3. An additional 30% shall be at least Level 2 EV Capable.

Calculations for the required minimum number of spaces equipped with Level 2 EVSE, Level 1 EV Ready spaces and EV Capable spaces shall all be rounded up to the nearest whole number.

Construction plans and specifications shall demonstrate that all raceways shall be a minimum of 1" and sufficient for installation of EVSE at all required Level 1 EV Ready and EV Capable spaces; Electrical calculations shall substantiate the design of the electrical system to include the rating of equipment and any on-site distribution transformers, and have sufficient capacity to simultaneously charge EVs at all required EV spaces including Level 1 EV Ready and EV Capable spaces; and service panel or subpanel(s) shall have sufficient capacity to accommodate the required number of dedicated branch circuit(s) for the future installation of the EVSE.

5.106.5.3.2 Other nonresidential buildings. In nonresidential new construction buildings that are not designated primarily for office use, such as those for retail uses:

1. When 10 or more parking spaces are constructed, 6% of the available parking spaces on site shall be equipped with Level 2 EVSE;
2. An additional 5% shall be at least Level 1 EV Ready.

Calculations for the required minimum number of spaces equipped with Level 2 EVSE

and Level 1 EV Ready spaces shall be rounded up to the nearest whole number

SECTION 24. AUTHORITY AND FINDINGS.

The following findings support that the above amendments and modifications are reasonably necessary because of local climatic, geological, or topographical conditions:

The City of Los Altos is located in Climate Zone 4 as established in the 2019 California Energy Code. Climate Zone 4 includes Santa Clara County, San Benito County, portions of Monterey County and San Luis Obispo. The City experiences an average of 19 inches of precipitation per year. In Los Altos, January is the rainiest month of the year while July is the driest month of the year. Temperatures average about 80 degrees Fahrenheit in the summer and about 40 degrees Fahrenheit in the winter. These climatic conditions along with the effects of climate change caused by Green House Gas (GHG) emissions generated from burning natural gas to heat buildings and emissions from Vehicle Miles Traveled results in an overall increase in global average temperature. Higher global temperatures are contributing to rising sea levels, record heat waves, droughts, wildfires, and floods.

The above local amendments to the 2022 California Green Building Standards Code are necessary to combat the ever-increasing harmful effects of global climate change. Implementation of the proposed code amendments will achieve decarbonization and provide an accelerated path to reduce GHG emissions. The proposed Ordinance containing these amendments would ensure that new buildings use cleaner sources of energy which helps meet the goal of cutting carbon emissions in half by 2030.

Increased Electric Vehicle Infrastructure integrated into building design benefits the health, welfare, and resiliency of Los Altos and its residents.

SECTION 25. AMENDMENT OF CODE: Title 12, Chapter 12.30 of the Municipal Code is hereby repealed.

SECTION 26. AMENDMENT OF CODE: Title 12, Chapter 12.30 of the Municipal Code is hereby added to read as follows:

Chapter 12.30 CALIFORNIA EXISTING BUILDING CODE

Section 12.30.10 Adoption of the California Existing Building Code.

There is hereby adopted by reference as if fully set forth herein, the 2022 California

Existing Building Code, contained in the California Code of Regulations, Title 24, Part 10, and also the International Existing Building Code 2021 Edition, published by the International Code Council, and each and all of its regulations and provisions. One copy is on file for use and examination by the public in the office of the Building Official.

SECTION 27. AMENDMENT OF CODE: Title 12, Chapter 12.32 of the Municipal Code is hereby repealed.

SECTION 28. AMENDMENT OF CODE: Title 12, Chapter 12.32 of the Municipal Code is hereby replaced to read as follows:

Chapter 12:32 CALIFORNIA HISTORICAL BUILDING CODE

Section 12.32.10 Adoption of the California Historical Building Code.

There is hereby adopted by reference as if fully set forth herein, the 2022 California Historical Building Code, contained in the California Code of Regulations, Title 24, Part 8, published by the International Code Council, is hereby adopted. There is one copy of said code on file in the office of the Building Official for use and examination by the public.

SECTION 29. AMENDMENT OF CODE: Title 12, Chapter 12.42 of the Municipal Code is hereby repealed.

SECTION 30. AMENDMENT OF CODE: Title 12, Chapter 12.42 of the Municipal Code is hereby added to read as follows:

Chapter 12.42 CALIFORNIA REFERENCED STANDARDS CODE

Section 12.42.10 Adoption of the California Referenced Standards Code.

There is hereby adopted by reference as if fully set forth herein, the 2022 California Referenced Standards Code, contained in the 2022 edition of the California Code of Regulations, Title 24, Part 12, published by the International Code Council, and each and all of its regulations and provisions. One copy is on file for use and examination by the public in the office of the Building Official.

SECTION 31. AMENDMENT OF CODE: Title 12, Chapter 12.68 of the Municipal Code is hereby repealed.

SECTION 32. AMENDMENT OF CODE: Title 12, Chapter 12.68 of the Municipal Code is hereby added to read as follows:

Chapter 12.68 UNDERGROUNDING UTILITIES

Section 12.68.010 Purpose.

Section 12.68.020 Undergrounding utilities.

Section 12.68.010 Purpose.

The purpose of this chapter is to improve and maintain the visual quality and public and private views in the city, as well as to protect and enhance the health and quality of life of its citizens, by reducing hazards along with the visual blight created by overhead utilities.

Section 12.68.020 Undergrounding utilities.

It is the intent of the city to ensure that all new utility services and relocated existing utility services are placed underground, including additions exceeding fifty (50) percent of floor area and/or seven hundred and fifty (750) square feet or more, excluding basements and any non-habitable floor areas. For the purpose of this section, removal of roof framing with associated exterior walls down to, or below the subfloor/slab shall be included in the above calculations. Therefore, the following shall apply:

- a. In areas served by existing overhead facilities, all new service drops shall be installed underground from the most convenient existing pole.
- b. Relocations and extensions of existing overhead facilities shall be prohibited; provided, however, relocation of existing poles shall be permitted in some instances pursuant to Section 13.20.160 of this municipal code.
- c. Residential properties that are served by utilities located in rear yards on standard lots with frontage on only one public right-of-way shall not be required to underground existing overhead services.
- d. The obligation to provide compliance with these underground utility regulations may not be evaded by performing a series of small additions undertaken over a three-year period and/or two code cycles. The original addition permit issuance date where these regulations were in effect shall be used for compliance.
 - i. Any submittal for building permits which exceed fifty (50) percent and/or seven hundred and fifty (750) square feet of existing floor areas (area calculations shall not include existing basement floor areas and any non-habitable floor areas i.e., garages) during the three-year period shall comply with undergrounding of utility regulations.
 - ii. No exception or waiver shall be granted from compliance with undergrounding utilities.

- e. The Building Official may only grant exceptions to these requirements in cases where access across adjacent property is necessary but is not legally or practically available.
 - i. To demonstrate an exception the property owner shall provide a plan showing the required utility design, communication with adjacent property owners indicating the lack of access allowed, and a letter from the utility company which indicates that no alternative configuration for undergrounding of utilities is possible.
- f. Completion of Work. Undergrounding utilities shall be completed prior to Building Final Inspection, and issuance of Certificate of Occupancy. No exception or waiver shall be granted which allows for a property owner to evade compliance with this requirement.

SECTION 33. CEQA. The City Council hereby finds and determines that this Ordinance has been assessed in accordance with the California Environmental Quality Act (Cal. Pub. Res. Code, § 21000 et seq.) (“CEQA”) and the State CEQA Guidelines (14 Cal. Code Regs. § 15000 et seq.) and is categorically exempt from CEQA under CEQA Guidelines, § 15061(b)(3), which exempts from CEQA any project where it can be seen with certainty that there is no possibility that the activity in question may have a significant effect on the environment. Adoption of the proposed Ordinance would not be an activity with potential to cause significant adverse effect on the environment because the changes made to the California Green Buildings Standards Code within are enacted to provide more protection to the environment, and therefore is exempt from CEQA. It is also exempt from CEQA pursuant to CEQA Guidelines, § 15308 which exempts actions taken by regulatory agencies for the enhancement and protection of the environment. As such, the Ordinance is categorically exempt from CEQA, and none of the circumstances set forth in CEQA Guidelines Section 15300.2 applies.

SECTION 34. The City Clerk is hereby directed to file a copy of this Ordinance with the California Building Standards Commission of the State of California.

SECTION 35. CONSTITUTIONALITY. If any section, subsection, sentence, clause, or phrase of this code is for any reason held to be invalid or unconstitutional, such decision shall not affect the validity of the remaining portions of this code.

SECTION 36. PUBLICATION. This ordinance shall be published as provided in Government Code section 36933.

SECTION 37. EFFECTIVE DATE. This ordinance shall be effective upon the commencement of the thirty-first day following the adoption date.

The foregoing ordinance was duly and properly introduced at a regular meeting of the City Council of the City of Los Altos held on November 15, 2022, and was thereafter, at a regular meeting held on November 29, 2022, passed and adopted by the following vote:

/
/
/
/

AYES: Council Members Fligor, Lee Eng, Weinberg, Vice Mayor
Meadows, and Mayor Enander
NOES: None
ABSENT: None
ABSTAIN: None

Anita Enander, MAYOR

Attest:

Angel Rodrigues, Interim CITY CLERK